

This file has been cleaned of potential threats.

To view the reconstructed contents, please SCROLL DOWN to next page.

TENDER FORM

प्लाज्मा अनुसंधान संस्थान

(भारत सरकार के परमाणु ऊर्जा विभाग का सहायता प्राप्त संस्थान)

इंदीरा ब्रिज के पास, भाट, गांधीनगर - 382428, भारत

दूरभाष: 079-23962020/23962021, फ़ैक्स: 079-23962277

निमंत्रण निविदा और निविदाकारों को निर्देश करने के लिए

Invitation to Tender and Instructions to Tenderers

The Purchase Officer, Institute for Plasma Research invites, online tenders in **TWO PART (INR QUOTE ONLY)** for supply of stores as detailed in the Purchaser's Tender documents. The conditions of contract and instructions to tenderers which will govern the contract pursuant to tender are given below.

If you are in a position to quote for the supply in accordance with the requirements stated in the attached Tender Form please submit your quotation **online. The quote should be in INR only.**

Tender submitted by **fax/cable/telegram or any mode other than online will NOT be considered at all** and all such tenders will be rejected without any notice to the tenderer.

Yours faithfully,

Purchase Officer-II

For and on behalf of Director, IPR
Institute for Plasma Research

Encl: as above.

INSTRUCTIONS FOR ONLINE SUBMISSION

- 1) It is mandatory for all the applicants to have **class-III digital signature certificate** from any of the licensed Certifying Applicant to participate in e-tendering.
- 2) In order to participate in online e-tendering process, it is mandatory for the applicants to have **user ID & password** to get access to the website www.tenderwizard.com/DAE. The applicants have to get registered their firm / company with the service provider, M/s ITI Limited for user ID & password. The registration shall be done by paying an annual registration fees to M/s ITI Limited and completing other formalities as mentioned in the website, www.tenderwizard.com/DAE. Validity of online registration is for one year from the date of its issuance and may be renewed by paying the applicable amount. For assistance/clarifications please contact Mr. Sunil K Patel at mobile 09624981992, e-mail: twhelpdesk426@gmail.com or nodalofficer.et@ipr.res.in or All India Help line No: 91-80-40482000/[18004255048](tel:18004255048), e-mail: daehelpdesk@tenderwizard.co.in.
- 3) The applicants, who have already obtained such valid user ID and password from M/s ITI Limited, for any other tender of DAE, need not obtain fresh user ID and password for the purpose of participation in the present tender.
- 4) The services for e-tendering in IPR/DAE is provided by M/s ITI Ltd., Tender wizard Help Desk Centre, # 24, 1st Floor, Sudha Complex, Near Havanoor Circle, 3rd Stage, 4th Block, Basaveshwaranagar, Bangalore - 560079, Ph:91-80-40482000/[18004255048](tel:18004255048), Telefax: 91-80-40482114, Email: daehelpdesk@tenderwizard.co.in.
- 5) The quotations shall be submitted online in the prescribed format before the date and time as mentioned in tender document. No other mode of submission is acceptable.
- 6) On successful e-payment of tender processing fees, the applicants can download the tender documents (including Excel sheets, if any) from the e-tendering portal.
- 7) Submission of the offer document after the due date and time shall not be permitted. Time being displayed on e-Tendering portal shall be final and binding on the applicant.
- 8) Applicants are advised to submit their documents well before the due date. IPR shall not be responsible for any delay in submission of documents for any reason including server and technical problems.
- 9) **Applicants are advised to fill all the mandatory fields (coloured cells) of the excel files of the Tender. If applicant keeps any mandatory cell blank, System will not allow to close/save the file.**
- 10) In case of any problem with the submission of the offer documents, the applicant may have the assistance of helpdesk or use the help manual given on the said website or mobile and e-mail mentioned elsewhere.

<p>प्लाज़्मा अनुसंधान संस्थान इंदीरा ब्रिज के पास, भाट, गांधीनगर - 382428 गुजरात राज्य दूरभाष: 079 23962020, 23962021 फैक्स: 079 23962277</p>	<p>INSTITUTE FOR PLASMA RESEARCH NEAR INDIRA BRIDGE, BHAT, GANDHINAGAR 382 428 GUJARAT STATE Phone: 079 23962020, 23962021 Fax: 079 23962277</p>
--	---

निविदा सूचना TENDER NOTICE NO: IPR/TN/PUR/TPT/ET/18-19/46

दिनांकित DATED 9-1-2019

निम्नलिखित के लिए प्रतिष्ठित और योग्य पार्टियों से ई-निविदा विधि के माध्यम से दो भाग में ऑनलाइन निविदा आमंत्रित की जाती है।

Online tender is invited in **TWO PART** through e-tendering mode from reputed and eligible parties for the following.

मद का विवरण Item Description	Design, Engineering, Manufacturing, inspection, factory acceptance testing, supply, installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400V, 400 Hz, Three phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel as per the specifications given in the tender documents.
निविदा प्रक्रिया शुल्क Tender Processing Fee	Tender Processing Fee of Rs.5,900.00 should be paid through electronic mode to M/s ITI Limited.
बयाना राशि जमा EMD	Rs.2,40,000.00 (Copy of Demand Draft to be uploaded with the quotation, Original DD should be sent to IPR on or before the specified closing date and time)
निविदा दस्तावेज वेबसाइट पर देखने और डाउनलोड करने के लिए उपलब्ध है Tender document available for view and downloading on website	09.00 hrs. on 10-1-2019 to 12.55 hrs. on 20-2-2019
आईपीआर में प्री-बिड मीटिंग Pre-Bid meeting at IPR	10.00 hrs on 22-1-2019
प्री-बिड मीटिंग स्पष्टीकरण Pre-Bid meeting clarification	09.00 hrs. on 10-1-2019 to 16.00 hrs. on 18-1-2019
निविदा ऑनलाइन जमा करने की अंतिम तिथि Closing of online submission of tenders	20-2-2019 at 13.00 hrs.
भाग-I के ऑनलाइन खोलने का समय और तिथि (तकनीकी बोली) Time and Date of online Opening of PART-I (Technical Bid)	20-2-2019 at 14.30 hrs.

भाग-II के ऑनलाइन खोलने का समय और तिथि (मूल्य बोली) Time and Date of online Opening of PART-II (Price Bid)	Will be declared later on
--	---------------------------

वेबसाइट www.tenderwizard.com/DAE पर अपने प्रश्नों को अपलोड करके निविदाकर्ता **18-1-2019** (16:00 बजे) तक निविदा दस्तावेज के बारे में स्पष्टीकरण (प्री-बिड) मांग सकता है। इसके अलावा, हमने स्पष्टीकरण पर चर्चा के लिए आईपीआर, गांधीनगर में **22-1-2019** को 10:00 पूर्वाह्न पर एक पूर्व-बोली बैठक आयोजित की है। स्पष्टीकरण **25-1-2019** (17:30 बजे) तक एक ही वेब पोर्टल www.tenderwizard.com/DAE पर अपलोड किया जाएगा।

The tenderer can seek clarifications (pre-bid) regarding the tender document up to 18-1-2019 (16:00 Hrs) by uploading their queries on website www.tenderwizard.com/DAE . Moreover, we have arranged a pre-bid meeting at IPR, Gandhinagar on 22-1-2019 at 10:00 AM to discuss on the clarifications. The clarifications will be uploaded on the same web portal www.tenderwizard.com/DAE by 25-1-2019 (17:30 Hrs).

विस्तृत निविदा सूचना, योग्यता मानदंड और निविदा दस्तावेज के साथ वेबसाइट www.tenderwizard.com/DAE पर निःशुल्क देखने और डाउनलोड करने के लिए उपलब्ध है। ई-निविदा प्रक्रिया में भाग लेने के लिए, उपर्युक्त ई-निविदा पोर्टल पर रजिस्टर करना अनिवार्य है और डिजिटल हस्ताक्षर प्रमाणपत्र (श्रेणी-III) होना आवश्यक है। बोलीदाता नए रजिस्ट्रेशन/टेन्डरिंग में सहायता के लिए पञ्जी हेल्पडेस्क से daehelpdesk@tenderwizard.co.in पर संपर्क कर सकते हैं, फोन नंबर: (80)-40482000/ 9624981992/18004255048

Detailed tender notice along with Eligibility criteria and Tender Document is available on website www.tenderwizard.com/DAE for free view and downloading. For participating in the e-tendering process, it is mandatory to get registered on the above e-tender portal and required to have Digital Signature Certificate (Class -III). For new registration/ tendering help, bidders may contact DAE Helpdesk at daehelpdesk@tenderwizard.co.in Phone No: (80)-40482000/ 9624981992/ 18004255048

इस निविदा सूचना की एक प्रति संस्थान की वेबसाइट www.ipr.res.in//purchasetenders.html पर भी उपलब्ध है। अधिक जानकारी के लिए, कृपया संपर्क करें: 079 23962020/2021, फ़ैक्स: 079 23962277।

A copy of this tender notice is also available on the Institute's website www.ipr.res.in//purchasetenders.html. For further information, please contact: 079 23962020/2021, Fax: 079 23962277.

TWO-PART TENDER SECTION – A

Invitation to Tender and Tendering Conditions

1.0 INVITATION TO TENDER

1.1 Institute for Plasma Research (IPR) invites online tenders for supply of Plant, Machinery, Equipment/Components to the specifications detailed in Section "C" to this tender document. The conditions of contract/purchase order which will govern the contract pursuant to the tender are as contained in Section "B" of this tender document. If you are in a position to quote for supply in accordance with the technical specifications indicated in Section "C" to this tender document and as per the conditions stipulated in this Section and Section B, please upload your offer in a manner and method specified below.

2.0 MANNER AND METHOD FOR SUBMISSION OF TENDERS

2.1 All tenderers in response to this invitation shall be submitted through online mode only. Tender submitted by **fax/cable/telegram or any mode other than online will NOT be considered at all** and all such tenders will be rejected without any notice to the tenderer.

2.1.1 **Part-I (Techno-commercial):** This part of the tender shall include/contain documents related to eligibility criteria, all technical details, technical specifications, drawings and also the commercial terms and conditions of contract for the supplies to be made and the services to be rendered **EXCLUDING ANY PRICE DETAILS THEREOF.**

Proof for fulfillment of eligibility criteria mentioned in Annexure-A should be uploaded along with the tender. If the tender is submitted without valid documents, we shall not consider your offer. Tenders received without proof of eligibility criteria will be rejected. The offers which meets the eligibility criteria will only be considered for evaluation.

2.1.2 **Part-II (Price):** This part should contain only the prices of the stores offered for the services to be rendered. Part-II (Price) should be furnished in accordance with the format provided by the Purchaser at Section "D" of this tender document

2.1.3 If tenderer includes prices of any nature in Part-I (Techno-commercial) of the tender such offers are liable for rejection without any notice to the tenderers.

3.0 EARNEST MONEY DEPOSIT (EMD)

3.1 The Tenderer shall submit, as part of its bid, interest free Earnest Money Deposit (EMD) for an amount as specified in the Tender Notice. In the case of foreign bidders, the EMD shall be submitted either by the principal or by the Indian agent and in the case of indigenous bidders;

the EMD shall be submitted by the manufacturer or their specifically authorized dealer/bidder. EMD shall be submitted by way of Demand Draft from **SBI/nationalized banks or any one of the scheduled banks mentioned in the bracket (Axis Bank, HDFC Bank, ICICI Bank and IDBI Bank)** issued in favour of "**Institute for Plasma Research**" and payable at **Ahmedabad**. **Tender received without EMD will be rejected at the discretion of IPR.**

(Copy of Demand Draft to be uploaded with the quotation, Original DD should be sent to IPR on or before the specified closing date and time)

- 3.2 The EMD of unsuccessful Tenderer will be discharged/returned after finalizing award of the Contract/placement of Purchase order.
- 3.3 The successful Tenderers EMD shall be discharged upon the Bidder submitting the Security Deposit as specified in the contract/purchase order, without any interest.
- 3.4 **Exemption from payment of EMD:** The firms registered with DGS&D, NSIC, DPS or Micro & Small Enterprises (MSEs) which are actual producers/manufacturers of tendered items are exempted from payment of EMD provided valid registration certificate is uploaded along with the offer. In the case of foreign bidders, payment of EMD is exempted if they submit their bid directly or through their Indian agent in **foreign currency** against the tender document bought by them, so that the order can be placed directly on their Principals.
- 3.5 **The EMD may be forfeited:**
 - 3.5.1 If a Tenderer withdraws or amends or modifies or impairs or derogates its bid during the period of bid validity specified by the Bidder on the Bid Form; or
 - 3.5.2 In case of a successful tenderer, if the tenderer fails to furnish order acceptance within 15 days of the order or fails to submit the Security Deposit within 21 days from the date of contract/order.

4.0 LATE/DELAYED TENDERS

- 4.1 Uploading of the offer document after the due date and time shall not be permitted. Time being displayed on e-Tendering portal shall be final and binding on the applicant.

5.0 OPENING OF TENDERS

- 5.1 Unless otherwise pre-opened or postponed with advance intimation to the tenderers, tender will be opened in two stages on the date and time indicated on e-Tendering portal.
- 5.2 Part-I (Techno-commercial) of the tender will be opened at the first stage on the due date and time indicated for opening on the e-Tendering portal while the Part-II (Price) will be opened at the second stage after completion of the evaluation of the Techno-Commercial Part (Part-I) of the tender.
- 5.3 While all the tenderers who uploaded tenders within the due date and time will be permitted to participate in the opening of Part-I (Techno-Commercial) of the tender on the due date and time indicated on e-Tendering portal, opening of the Part-II (Price) of the tender can be attended to only by such of those tenderers whose Part-I (Techno-Commercial) of the tenders are found to be technical suitable/

acceptable to the Purchaser and to whom intimation thereof is given by the Purchaser by Email/letter or through e-Tendering portal.

- 5.4 The tenderers whose Techno-commercial part (Part-I) are found suitable/acceptable to the Purchaser, will be given seven days advance intimation by the Purchaser to enable such tenderers to depute their representative to participate in the opening of the Part-II (Price) of the tender. The technically unqualified tenderers will neither be given any intimation about the date and time of opening of Part-II (Price) of the tender nor will they be permitted to participate in the opening of the same. **Part-II (Price) of the technically disqualified tenderers will not be opened.**

6.0 AUTHORITY LETTER

- 6.1 The tenderers who wish to participate in the opening of the tenders may depute their representatives to IPR on the respective due date and time as indicated in the tender notice with an authority letter addressed to the Purchase Officer which should be produced to the officers who are opening the tenders, on demand to prove the bonafides of the representative who participates in the opening of the tender. In case the representative of the tenderer fails to produce such an authority letter on behalf of the tenderer, he will be debarred from participating in the opening of the tenders.

- 6.2 The tenderers representative, who reaches the venue of the tender opening late, i.e. after the starting time specified for opening of the tenders, may not be allowed to take part in the tender opening. It should be noted that only one representative of each tenderer will be permitted to participate in the tender opening.

7.0 EVALUATION OF TENDER

- 7.1 Evaluation of tender shall be based on all inclusive landed cost.

8.0 PURCHASER'S RIGHTS TO REJECT QUOTATION

- 8.1 The Purchaser reserves the right to reject any quotation without assigning any reason thereof.

9.0 TECHNICAL CLARIFICATIONS

- 9.1 After opening of Part-I (Techno-commercial) of the tender, if it becomes necessary for IPR to seek clarifications from the tenderers, the same will be sought for from the tenderers.

10.0 DATE FOR OPENING OF PART-II (PRICE):

After completion of technical evaluation, Part-II (Price) of only technically qualified tenderers shall be opened. The date and time of opening of Part-II (Price) shall be intimated only to the technically qualified tenderers. Whose Part-I offers have been found suitable will only be permitted to participate in the opening of the Part-II (Price) of the tender.

11.0 HOLIDAYS

If the date (s) specified for receipt and opening of the tenders is/are declared as holidays abruptly by the competent authority due to any administrative reasons, then the date(s) for opening of tenders will get postponed automatically to the next working day. As for instance, if the due date for receipt of tender and its opening falls on 3rd of a particular month and if the 3rd day of the month is declared as a holiday, then the

opening date of tender will stand automatically postponed to 4th day of the month at the same time. However, due date for submission of tender online will remain same as mentioned in the tender notice.

12.0 VALIDITY OF OFFERS

Offers shall be kept valid for acceptance for a period of 120 (One hundred twenty) days from the date of opening of Part-II (Price) of the tender. Offers with shorter validity period will be liable for rejection.

13.0 CATALOGUES/TECHNICAL LITERATURE

Vendor shall upload all necessary catalogues/drawings technical literature data as are considered essential for full and correct evaluation of the offers shall invariably accompany the Part-I (Techno-Commercial) of the tender. The quotations are liable to be ignored if this condition is not complied with.

14.0 TERMS AND CONDITIONS OF THE CONTRACT

It must be clearly understood that any contract concluded pursuant to this invitation to tender shall be governed by the General Conditions of the Contract as contained in Section "B" of this tender document. Tenderers must therefore, take special care to go through these general conditions of contract and in exceptional cases if any deviations are proposed, these must be clearly indicated in the Part-I of the tender as a separate annexure instead of merely enclosing their printed conditions of Sale. Tenders made subject to counter conditions or far too many deviations from the general conditions of contract, i.e. Section "B" of this tender document are liable to be ignored. It should also be realised that failure to bring out deviations from the General Conditions of Contract contained in Section "B" of this tender document will imply that the tenderer is willing to execute the contract as per the Purchaser's terms and conditions of contract.

15.0 TENDERING CONDITIONS FOR BIDS

- 15.1 The prices quoted must be FIRM and preference will be given to such tenders. In exceptional cases (e.g. items involving substantial use of raw materials susceptible to sharp fluctuations in prices) if prices quoted subject to variation it shall be on the basis of a standard 'Price Variation Formula'. The basis for calculation shall be very clearly stated. The responsibility for furnishing the documentary evidence for price variation lies with the vendor. Here again preference will be given to the tenders with a specific ceiling on escalation.
- 15.2 Prices quoted by the tenderer should include all charges involved for direct and safe-delivery of the stores to the consignee/place of delivery indicated in the tender document. If a tenderer so desires, separate lump sum charges for safe-delivery of the stores to the consignee/purchaser's site, could be furnished. However, the purchaser reserves the right to call for break-up. The purchaser will neither undertake responsibility for transit insurance nor pay for it separately.
- 15.3 In respect of tenders on Ex-works basis, in case the tenderer has not mentioned in the offer packing, forwarding and transportation charges for safe delivery up to Purchaser's site, 2% of the price quoted towards packing (in respect of both local and outstation firms), 1% of the basic price quoted towards safe delivery charges in respect of local tenderer and 3% of the basic price quoted towards safe delivery charges in

respect of outstation firm will be added for comparison of offers on safe door delivery at Purchaser's site.

- 15.4 The stores shall neither be despatched under 'owner's risk' nor consigned to 'self', but only to the consignee's name and address indicated in the Purchase order. Non-adherence to this condition shall make the contractor liable to bear all consequential penalties/expenses such as demurrage, wharf age, etc. which the Purchaser may incur.
- 15.5 The consignee will, as soon as possible, but not later than 45 days from the date of arrival of stores at destination notify the contractor of any loss or damage to the stores that may have occurred during transit to enable the contractor to repair/rectify the defects/damages or replace the goods as is appropriate, free of all charges. In case it is desired by the contractor for returning of the material to them all expenses towards transportation etc. will be borne by the supplier and also will furnish bank guarantee towards the cost of material.
- 15.6 In case an Indian supplier/Agent furnishes an offer for supply of outrightly imported stores, the price of such stores shall be quoted in Indian Rupees for delivery to the consignee's premises exclusive of import duties and on firm price basis.
- 15.6 **Conditional Discount:** In case the tenderer offers any conditional discount with regard to acceptance of their offer within a specific payment terms, delivery, quantity etc. the purchaser will not take into consideration such conditional discount while evaluating their offer.

16.0 SPARES AND ACCESSORIES

- 16.1 Tenders for plant/machinery/equipment/component shall also indicate prices for essential accessories, optional accessories and spares necessary for satisfactory operation of the plant/machinery/equipment.
 - 16.1.1 for a period of two years and
 - 16.1.2 for a period of five years
- 16.2 Prices for accessories and spares shall be itemized. Tenders where only lumpsum prices are indicated are liable to be ignored. Particular care must be taken to list out each item of spare and quantity recommended and also the individual price for these items. These details should be included only in Part-II (Price) of the tender. However, a list of spares and accessories without Price should be included in Part-I (Techno-Commercial) of the tender.

17.0 QUANTITY

The purchaser reserves the right to accept tenders for any quantity of his choice and the tenderer shall be bound to accept a contract for any quantity. The Purchaser also reserves the right to accept or reject lowest or any tender in full or in part without assigning any reasons.

18.0 STATUTORY LEVIES SUCH AS CUSTOMS DUTY, GOODS AND SERVICE TAX

18.1 CUSTOMS DUTY

- 18.1.1 The Purchaser is entitled for assessment of customs duty at the concessional rate as per Customs Notification No. 51/96-Custom dated 23.7.1996 issued by the Department of Revenue, Ministry of Finance, as amended from time to time, in respect of purchases made for the Research Institutions under the Department of Atomic Energy and the Purchaser will obtain the requisite

- certificate from the appropriate authority.
- 18.1.2 In case an Indian vendor/agent submits an offer for supply of outrightly imported stores in Indian Rupees, they should quote price for free and safe delivery of stores at destination.
- 18.1.3 Wherever, against a requirement, both indigenous as well as imported offers are received, the offers for imported stores will be evaluated on the basis of the total landed cost after loading the custom duty and other levies as may be applicable from time to time for taking purchase decision.
- 18.1.4 High Seas sale will not be considered.

18.2 **FLUCTUATION IN THE CUSTOMS DUTY**

- 18.2.1 Unless otherwise specifically agreed to in terms of the Contract, the purchaser shall not be liable for any claim on account of fresh imposition and /or increase in Customs Duty on raw materials and/or components used directly in the manufacture of the contracted stores, taking place during the pendency of the contract.

- 18.3 **Offers from Indian Agents on behalf of foreign suppliers:** In case the tender is submitted by an Indian supplier/Indian agent on behalf of their foreign supplier/ principals, following documents should be submitted with the tender, failing which, their offer is liable to be ignored.

- 18.3.1 Photocopy of the Agency Agreement between the Principals and the Indian Agent showing the percentage or the quantum of agency commission payable and a Letter of Authority from the Principals authorizing the Indian Agents to submit the tender on their behalf.
- 18.3.2 The type and nature of after sales services to be rendered by the Indian Agent.
- 18.3.3 Both Indian Agent and Principal/OEM cannot bid simultaneously for the same item/product in the same tender.
- 18.3.4 The Indian Agents are allowed to quote on behalf of only one foreign Principal/ Supplier against this tender.
- 18.3.5 Copy of Registration Certificate with DGS&D or DPS.

18.4 **GOODS AND SERVICE TAX**

- 18.4.1 GOODS AND SERVICE TAX where legally leviable as per relevant HSN code will be admitted and reimbursed at the rate applicable during original delivery date.
- 18.4.2 GOODS AND SERVICE TAX intended to be claimed should be distinctly shown separately along with the price quoted. Where this is not done, no claim for GOODS AND SERVICE TAX will be admitted at any later stage and on any ground whatsoever.
- 18.4.3 The Purchaser is entitled for assessment of GST at the Concessional rate as per Notifications issued by the Government, as amended from time to time, in respect of purchases made for the Research and Development applications under the Department of Atomic Energy and other R&D units.
- 18.4.4 **GST for R&D Unit:** Goods and Service Tax (GST) wherever applicable will be paid extra at actual during the delivery period stipulated in the Purchase order. In terms of notifications issued by the Central Government and State Governments, R&D units of Department of Atomic Energy are entitled for IGST @ 5% or CGST @ 2.5% and SGST @ 2.5% as applicable for stores covered under the Purchase Order.

- 18.4.5 **GST for Services:** As applicable. Specify the SAC codes wherever services are involved.
- 18.4.6 It would be the responsibility of the contractor to ensure that relevant certificate is obtained from the Purchaser before effecting the delivery of goods ordered failing which the excess tax paid by the contractor shall not be reimbursed by the Purchaser.
- 18.4.7 When GOODS AND SERVICE TAX is claimed as extra by the vendor in general and on packing charges in particular, the following certificates should be submitted by the vendor to the Paying Authority on the bills itself.
- 18.4.8 Certified that the goods and packing charges on which GOODS AND SERVICE TAX has been charged have not been exempted under the Central Sales Tax or the State Sales Tax Act or the rules made there-under and the amount charged on account of GST on these goods and packing charges are not more than what is payable under the provision of relevant Act or the rules there-under.
- 18.4.9 Certified further that we have actually paid GOODS AND SERVICE TAX and are being assessed to GST on packing charges and also that where there are statutory exemption under the Relevant Act/Law of the State Government concerned, we have availed ourselves of it and certified non-availability of such a provision for GST on packing charges wherever claimed.
- 18.4.10 Certified further in respect of amount claimed into the bill no claim is pending for refund/or admissible. Certified that in the event of our getting refund in whole or in part of the element of GOODS AND SERVICE TAX on packing charges claimed from Government, we shall pass on the benefit to the Purchaser by remitting to Government the amount equivalent to the amount of refund obtained by us.
- 18.4.11 Further certified that we abide by the all the provisions of Acts of Governemnt and rules made thereunder especially regarding anti-profiteering provisions.
- 18.4.12 Certified further that we (our Branch or agent) _____

 (address) are registered as dealers in the State of _____
 under Local Regn. No. _____ and in the State of _____
 under Central Regn. No. _____ for the
 purpose of State/Central Tax.
 (Stamp & Signature of the Vendor)
- 18.4.13 The vendor shall solely be responsible for declaration of Goods and Service Tax made in his invoice and shall indemnify the purchaser from any claim or its liability from concerned authorities at any stage.
- 18.4.14 Certificate with each bill to the effect that no refund has been obtained in respect of the reimbursement of GST made to vendor during three months immediately preceding the date of the claim covered by the relevant bill.
- 18.4.15 AN UNDERTAKING to the effect that in case any refund of GST is granted to the vendor by concerned authorities in respect of stores supplied under the contract, they shall pass on the credit to the purchaser immediately alongwith a certificate from their Director/Manager/Proprietor/ Accountant to the effect that the credit so passed on relates to the GST originally paid for the stores

supplied under the contract. In case of their failure to do so within 10 days of the issue of the refund orders to them by the Authorities, the purchaser would be empowered to deduct a sum equivalent to the amount refunded by the authorities without any further reference to the vendor, from any of their outstanding bills against this or any other pending Government Contracts and that no dispute on this account would be raised by the vendor.

18.4.16 Statutory Deductions, as applicable shall be made from the supplier's bill.

18.5 **DEDUCTION OF TAX AT SOURCE (TDS)**

As per Government of India rules, it is mandatory that income tax shall be deducted at source at applicable rates as per relevant act, rules and notifications issued by the government from time to time.

18.5.1 **In case of Indigenous Vendors** (Indian Suppliers who provide indigenous products and services, Indian subsidiaries with permanent establishment in India who supply imported goods and services and paid in Indian currency only): Tax deducted at source will be applicable under Section 194-C for carrying out any work (including supply of labour for carrying out any work) in pursuance of contract as per Income Tax Act 1961. In case of technical or professional services, TDS will be applicable as per under Section 194-J of Income Tax Act 1961.

18.5.2 **In case of Foreign Vendors** (Foreign Suppliers who provide goods from abroad paid in foreign currency and providing technical services by Indian subsidiary paid in Indian currency): The TDS is applicable where services are rendered in India directly or through their Indian counter part against foreign Purchase order / Contract as per the provision of under Section 195 of Income Tax act of India. Wherever DTAA (Double Taxation Avoidance Agreement) agreement exists between India and the supplier country the provisions of the agreement shall be applicable. For getting benefit of DTAA (Double Taxation Avoidance Agreement), the following documents must be submitted, otherwise full TDS will be deducted.

- a) No Permanent Establishment in India certificate
- b) Tax Residency Certificate (TRC) issued by Tax authorities of their country
- c) Form 10F if TRC does not contain required details
- d) PAN (Permanent Account Number) details issued by Indian Income Tax Authority

Important Note:

- a) Where bifurcation is inappropriate and unacceptable for supply of material and providing services the purchase order / contract will be treated as **Composite Contract** and TDS will be deducted on whole contract / purchase order value as per applicable rate.
- b) TDS or any other leviable taxes or duties, if applicable, shall be deducted recovered from the Supplier's bill and necessary certificate will be issued to the supplier.

- c) Details on relevant sections of Income Tax Act and DTAA treaties can be obtained from [https://www.incometaxindia.gov.in/ Pages/acts/income-tax-act.aspx](https://www.incometaxindia.gov.in/Pages/acts/income-tax-act.aspx).

19.0 FLUCTUATION IN STATUTORY LEVIES

Unless otherwise specifically agreed to in terms of the Contract, the purchaser shall not be liable for any claim on account of fresh imposition and/or increase in statutory levies on raw materials and/or components used directly in the manufacture of the contracted stores, taking place during the pendency of the contract. However, any reduction in statutory levies on these raw materials and/or components must be passed on to the Purchaser.

20.0 SAMPLES/PROTOTYPES

If any called for shall be submitted free of all charges by the Tenderer and the Purchaser shall not be responsible for any loss or damage thereof for any reason whatsoever. In the event of non-acceptance of the tender, the tenderer will have to make arrangements to remove/collect the sample/prototypes at his own expenses.

21.0 QUANTITIES

Quantities indicated are approximate only and one or more of the items of the stores tendered, or a portion of any one or more of the items of such stores may be accepted and the tenderer notwithstanding that his Tender has not been accepted in whole shall be bound to supply contracted quantity to the Purchaser.

22.0 SUBMISSION OF DRAWINGS

The tenderer shall furnish all drawings pertaining to the plant/machinery/ equipment/component to the Purchaser along with the tender for correct understanding and appreciation of the tender in quadruplicate. Besides, tenderers should also furnish general arrangement, schematic and such other drawings prescribed by the Purchaser within 4 weeks from the date of receipt of a Purchase Order for approval. Such drawings should be furnished along with Part-I (Techno-Commercial) of the tender. Tenderer's drawing will form part of the purchase order/contract only after these are approved by the Purchaser.

23.0 INSTALLATION AND COMMISSIONING

- 23.1 Wherever, the purchaser's invitation to tender calls for installation and commissioning or supervision of installation and commissioning of the instrument/equipment by the tenderer, the tenderer must clearly and separately quote the prices for the supply of the stores and the charges and the terms for installation and commissioning or supervision of installation and commissioning, as the case may be. The charges towards installation and commissioning should not be included in the price of the stores.
- 23.2 In respect of contracts involving installation and commissioning by vendors including overseas vendors where identifiable charges for the same has been quoted by the vendor, he shall bear the Income-tax liability as per the rates prevailing at the time of undertaking the job in accordance with the Income-tax Act in force in India.

23.3 Wherever, the scope of the contract includes installation and commissioning, it shall be the sole responsibility of the contractor to undertake the installation and commissioning as and when called for, by the Purchaser.

24.0 INSPECTION

24.1 The Contractor shall be responsible for and perform all inspection and testing required in accordance with the contract/purchase order and specifications included therewith.

24.2 The Purchaser may at his option depute his representative for inspection of the stores to be supplied under the contract or authorize and nominate a Quality Surveillance Agency of his choice for the purpose hereinafter called, in either case, the inspection.

24.3 The supplier shall give notice of readiness for inspection to the Purchaser so that the Inspector can be present at the requisite time. In such an event delivery shall not be effected until an authorization or shipping release is obtained from the Purchaser.

24.4 The contractor shall allow reasonable facility and free access to his work/factory and records to the inspector for the purpose of inspection or for ascertaining the progress of delivery under the contract.

25.0 FACTORY REGISTRATION/SHOP & ESTABLISHMENT CERTIFICATE

The tenderers shall upload the copy of the Factory Registration/License or Shop & Establishment Certificate as applicable, along with the tender, failing which the tenders are liable for rejection.

26.0 PRODUCTS WITH ISI MARK

26.1 Products with ISI mark will be preferred.

26.2 In respect of following categories of item, Purchaser will consider offers for products with ISI mark only:

- Fire Extinguisher
- Building Material
- PVC Pipes & fittings
- Agricultural Implements & sprayers
- Medical instruments such as syringes, needles, BP apparatus etc.

27.0 SHOP/FACTORY EVALUATION, QUALITY SURVEILLANCE /INSPECTION AND SUBMISSION OF PROGRESS REPORTS

27.1 The Purchaser or his technical authorities may at his option and prior to evaluation of the tender depute his Inspector or any quality surveillance Agency of his choice to the factory/workshop of the tenderer to assess and establish the manufacturing capability etc. of the tenderer. Similarly, the Purchaser may also depute his inspector/Quality Surveillance agency of his choice for inspection of the plant/machinery/equipment/component during the various stages of manufacture in such an event the tenderer/contractor shall:-

27.1.1 Allow reasonable facility and free access to his factory/work/ records to the Inspector for the purpose of inspection or for ascertaining the progress of manufacture and delivery.

27.1.2 Provide the drawings, toolings, gauges, instruments etc. required for carrying out the inspection work.

- 27.1.3 Produce an inspection plan to the Purchaser's satisfaction notifying him when check points on the plan are imminent.
- 27.1.4 Not supply or deliver the plant/machinery/equipment/ component unless and until a Shipping Release or an authorisation for despatch is obtained in a format provided by the Purchaser. Failure to comply with this instruction will not only result in withholding of the payment to the contractor/supplier, but also hold the tenderer/contractor liable for payment of compensation to the Purchaser due to delay in clearance of the Equipment/plant/machinery/ component from the carriers.

28.0 INSTRUCTION MANUAL

In respect of plant/ machinery/ equipment/ instrument/ apparatus, where instruction/ operation manual is normally necessary to enable the user to put the plant/machinery/equipment/instrument/ apparatus to proper use, the Contractor shall furnish such an instruction/operation manual specific to the stores being supplied along with the plant/machinery/equipment/instrument/apparatus. The Contractor shall clearly specify in the offer about his readiness to supply instruction/operation manual

29.0 PACKING

- 29.1 Tenderers shall note that packing for shipment shall be in accordance with the instructions outlined in this tender document, each package shall be limited to the size and weights that are permissible under the existing Air and Sea limitations. Even when no packing specification is included in the invitation to tender, it will be Supplier's responsibility to provide appropriate packing depending upon the nature of the supply and the transportation and handling hazards.
- 29.2 The equipment shall be so packed and protected as not to suffer deterioration, damage or breakage during shipment and storage in a tropical climate.
- 29.3 Each package shall be properly labeled to indicate the type and quantity of material it contains, the purchase order number, its dimensions and weight and any other necessary data to identify the equipment and relate it to contract.

30.0 DEVIATIONS TO PURCHASER'S SPECIFICATIONS AND CONDITIONS OF CONTRACT

- 30.1 If any deviation or substitution from the technical specifications contained in Section "C" to this tender document is involved, such details should be clearly indicated in Part-I (Techno-Commercial) and should be added as an annexure to Part-I (Techno-commercial) of the tender as otherwise it shall be an admission on the part of the tenderer that he will supply the equipment as specified by the Purchaser. Similarly, deviations to the Purchaser's General Conditions of Contract/Special Conditions of Contract contained in Section "B" of this tender document shall be indicated by the tenderer in another annexure to Part-I (Techno-commercial) of the tenderer.

30.2 Part-II (Price) should be furnished in accordance with the format provided by the Purchaser at Section “D” of this tender document.

31.0 DELIVERY

Tenderer should note that no tender will be considered by the Purchaser unless the Tenderer can meet the delivery schedule specified by the Purchaser. All equipments/machinery/plant/ component covered by this tender document should be supplied on or before _____ or _____ month from the date of approval of drawings or ____ month from the date of receipt of free issue materials. The prices quoted by the tenderer should include all charges involved for direct and safe delivery of the items by Road to the project site of the Purchaser. If a tenderer so desires/separate lumpsum charges for transportation and safe delivery to Purchaser’s site could be furnished. Purchaser will neither undertake responsibility for transit insurance nor pay for it separately. No other, delivery term will be accepted by the Purchaser.

32.0 ACCEPTANCE OF TENDERS

32.1 The purchaser shall be under no obligation to accept the lowest or any other tender and shall be entitled to accept or reject any tender in part or full without assigning any reasons whatsoever.

32.2 Acceptance of tenders by the Purchaser will be sent by fax, E-mail, letter etc. within the validity date of the tender and such a fax, letter etc. would then be followed by a formal purchase order/contract. The tenderer whose offer is accepted will proceed with the execution of the contract on the basis of such advance acceptance of tenders without waiting for a formal purchase order/contract, and will be responsible to seek and obtain whatever clarifications that are necessary from the Purchaser to proceed with the manufacture without waiting for a formal purchase order/contract and delivery period will be reckoned from the date of the Letter of Intent.

33.0 SETTLEMENT OF COMMERCIAL TERMS AND CONDITIONS OF CONTRACT

In case the commercial terms and conditions of sale/contract stipulated in Part-I (Techno-commercial) of the tender submitted by the tenderer are at variance with the Purchaser’s General Conditions of all Contracts/Special Conditions of Contract stipulated in Section “B” of this tender document, the Purchase Officer will settle the commercial terms and conditions of contract with the tenderers chosen for award of the contract by holding discussions with them OR by sending Fax/Letter/E-mail etc. In case the concerned tenderer to whom an intimation thereof is given does not respond/fail to respond to communication sent by the Purchaser within the date specified, his tender is liable for rejection at the discretion of Director, IPR and no complaints whatsoever will be entertained from the tenderer for rejection of this tender. The tenderers should not discuss with the technical authorities/user department any of the commercial terms and conditions of contract and any agreement/understanding reached between the tenderer and the technical authorities will not be valid and binding.

34.0 **COMPLIANCE WITH THE SECURITY REQUIREMENTS OF THE PURCHASER**

The Contractor shall strictly comply with the Security Rules and Regulations of the Purchaser in force and shall complete the required formalities including verification from Police and any other authority and obtain necessary prior permission for entry into the Purchasers premises, wherever authorized by the Purchaser.

35.0 **PAST PERFORMANCE**

In case the past performance of the tenderer is not found to be satisfactory with regard to quality, delivery, warranty obligation and non-fulfillment of terms and conditions of the contract, their offer is liable to be rejected by the purchaser.

36.0 **CAPACITY & FINANCIAL STANDING**

In case it is found that the tenderer does not possess the requisite infrastructure, capacity, capability and their financial standing is not satisfactory, such tender is liable to be rejected by the Purchaser.

37.0 **CONFIDENTIALITY**

Drawings, specifications, prototypes, samples or any other correspondence/details/information provided by the Purchaser relating to the tender or the contract shall be kept confidential by the contractor, and should not be disclosed or passed on to any other person/firm without the prior written consent of the purchaser. This clause shall apply to the sub-contractors, consultants, advisers or the employees engaged by the Contractor.

38.0 **RESTRICTED INFORMATION CATEGORIES UNDER SECTION 18 OF THE ATOMIC ENERGY ACT, 1962 AND OFFICIAL SECRETS UNDER SECTION 5 OF THE OFFICIAL SECRETS ACT, 1923**

Any contravention of the above mentioned provisions by the contractor, sub-contractor, consultant, adviser or the employees of the contractor will invite penal consequences under the aforesaid legislation.

39.0 **PROHIBITION AGAINST USE OF THE NAME OF ANY INSTITUTION OF DEPARTMENT OF ATOMIC ENERGY WITHOUT PERMISSION FOR PUBLICITY PURPOSES**

The Contractor or sub-contractor, consultant, adviser or the employees engaged by the contractor shall not use the name of any Institution of Department of Atomic Energy for any publicity purpose through any public media like Press, Radio, TV or Internet without the prior written approval of the Purchaser.

40.0 **FREE ISSUE MATERIAL** *(This clause shall apply only to contracts for supply of fabricated equipment with purchaser's Free Issue Materials (FIM)).*

40.1 Wherever contracts envisage supply of Free Issue Material (FIM) by the Purchaser to the contractor, such Free Issue Material shall be safeguarded by an insurance policy to be provided by the Contractor at his own cost for the full value of such materials and the insurance policy shall cover, the following risks specifically and shall be valid for six months beyond the contractual delivery date.

- **Risk to be covered:** Any loss or damage to the Purchaser's material due to fire, theft, riot, burglary, strike, civil commotion, terrorist act, natural calamities etc. and any loss or damage arising out of any other causes such as other materials falling on purchaser's materials.
- **Insured by:** (Name of the Contractor)
- **Beneficiary:** Institute for Plasma Research, Near Indira Bridge, Bhat, Gandhinagar-382428.
- **Amount for which insurance policy to be furnished:** The amount will be indicated in the respective contract.

Free Issue Material (FIM) will be issued to the Contractor only after receipt of the Insurance Policy from the Contractor. The contractor shall arrange collection of the FIM from the Purchaser's premises and safe transportation of the same to his premises at his risk and cost.

Notwithstanding the insurance cover taken out by the Contractor as above, the contractor shall indemnify the purchaser and keep the Purchaser indemnified to the extent of the value of free issue materials to be issued till such time the entire contract is executed and proper account for the FIM is rendered and the left over/surplus and scrap items are returned to the Purchaser. The contractor shall not utilize the Purchaser's free issue materials for any job other than the one contracted out in this case and also not indulge in any act, commission or negligence which will cause/result in any loss/damage to the Purchaser and in which case, the Contractor shall be liable to the Purchaser to pay compensation to the full extent of damage/loss. The Contractor shall be responsible for the safety of the free issue materials after these are received by them and all through the period during which the materials remain in their possession/control/ custody. The free issue materials on receipt at the Contractor's works shall be inspected by them for ensuring safe and correct receipt of the material. The Contractor shall report the discrepancies, if any, to the Purchaser within 5 days from the date of receipt of the material. The Contractor shall take all necessary precautions against any loss, deterioration, damage or destruction of the FIM from whatever cause arising whilst the said materials remain in their possession/custody or control. The FIM shall be inspected periodically at regular intervals by the Purchaser for ensuring safe preservation and storage. The contractor shall also not mix up the FIM with any other goods and shall render true and proper account of the materials actually used and return balance remaining unused material on hand and scrap along with final product and if it is not possible within a period of one month from the date of delivery of the final product covered by this purchase order. The Contractor shall also indemnify the Purchaser to compensate the difference in cost between the actual cost of the FIM lost/damaged and the claim settled to the Purchaser by the insurance company. The decision of the Director, Institute for Plasma Research, as to whether the Contractor has caused any loss, destruction, damage or deterioration of the FIM while in his possession, custody or control from

whatever cause arising and also on the quantum of damage suffered by the government, shall be final and binding upon the Contractor.

41.0 EXPORT LICENCE/EXPORT PERMISSION

41.1 It is entirely the responsibility of the vendors who are quoting for materials of foreign origin to ensure obtaining export permission/licence/authorisation as required from the respective Government before arranging shipment. This Department would not accept post supply inspection by any agency/authority of any foreign country. It is, therefore, necessary that the vendors offering materials from foreign countries shall have thorough knowledge of export contract regulations in vogue in those countries.

41.2 The vendors shall indemnify the purchaser against any consequences in respect of any end-use declaration they/their overseas Principals may furnish to the government/government agencies of the country of origin of the materials, while seeking export permission/licence. Post supply inspection, contrary to the terms and conditions of purchaser's contract shall be deemed to be null and void.

42.0 END USE CERTIFICATE

42.1 Whenever an End-use Certificate is desired by the vendor, the same shall be clearly mentioned in the quotation and the purchaser shall provide an Enduser Certificate as per the format given below. The Purchaser will not provide any other document/declaration in this regard.

END USER STATEMENT:

"We hereby certify that the item/s i.e. _____, being procured from M/s _____ against our Purchase Order No. _____ dated _____ will be used for _____. We also certify that the item/s will not be used in designing, developing, fabricating or testing of any chemical, biological, nuclear, or weapons of mass destruction or activities related to it. It is further certified that we will not re-export the Item/s prior to obtaining permission from the concerned authorities as may be required".

43.0 COUNTRY OF ORIGIN

43.1 Wherever the tenders are for imported stores, the Country of Origin of the stores must be clearly specified in the quotation.

44.0 LIABILITY

44.1 Vendors shall be liable for any damage to the purchaser or any third party out of any patent or latent defect in the goods supplied by him or sub-standard services rendered by him.

45.0 RIGHT TO REJECT QUOTATION

45.1 The Purchaser reserves the right to reject any quotation, which is not in conformity with the above instructions.

45.2 The Purchaser also reserve the right to reject any quotation without assigning any reason whatsoever.

46.0 **PRICE / PURCHASE PREFERENCE**

Purchase/Price preference to industries will be given as per the policy of the Government of India in force at the time of evaluation provided their offer is in compliance with the conditions of the policy.

47.0 **PERMANENT ACCOUNT NUMBER (PAN)**

47.1 Vendors are required to upload a true copy of the PAN Card/Letter issued by the Income-tax Department, failing which the tenders are liable to be rejected.

48.0 MSE bidders should declare their UAM (Udyog Aadhar Memorandum) number on CPPP portal to avail benefits as per Public Procurement Policy for MSE's order 2012.

49.0 The bidder shall not be under a declaration of ineligibility for corrupt or fraudulent practices or blacklisted with any of the Government Agencies.

Any additional conditions attached to this Invitation to Tender shall also form part of the contract conditions.

SECTION 'B'

**GENERAL CONDITIONS OF
CONTRACT**

**INSTITUTE FOR PLASMA RESESARCH
PURCHASE SECTION**

**GENERAL CONDITIONS OF ALL
CONTRACT**

&

**SPECIAL CONDITIONS OF CONTRACT
GOVERNING SUPPLIES OF
PLANT AND MACNHINERY**

GENERAL CONDITIONS OF CONTRACT

1. DEFINITIONS

- 1.1 The term 'PURCHASER' means the Institute for Plasma Research or its successors or assigns.
- 1.2 The term 'PARTICULARS' means the following:
 - 1.2.1 Specification
 - 1.2.2 Drawing
 - 1.2.3 Sealed pattern denoting a pattern sealed and signed by the Inspector
 - 1.2.4 Proprietary make denoting the produce of an individual firm
 - 1.2.5 Any other details governing the construction manufacture and/or supply as existing for the contract.
- 1.3 The term 'CONTRACTOR' or 'SUPPLIER' means, firm or company with whom or with which the order for the supply of stores is placed and shall be deemed to include the Contractors/Successors (approved by the Purchaser), representatives, heirs, executors and administrators unless excluded by the contract.
- 1.4 The term 'CONTRACT' or 'PURCHASE ORDER' means and comprises of a Letter or Email or ink signed or digitally signed document conveying acceptance of Contractor's offer and invitation to tender, tender containing offer, advance acceptance of offer, general and special conditions of contract specified in the acceptance of offer and any subsequent amendments/alterations thereto made on the basis of mutual agreement.
- 1.5 The term 'STORES' or 'MATERIAL' means, the goods specified in the contract/purchase order which the contractor has agreed to supply under the contract.
- 1.6 The term 'SUB-CONTRACTOR' or 'SUB-SUPPLIER' means any contractor or supplier engaged by the contractor or the supplier with the prior approval of the Purchaser in relation to the contract/purchase order.
- 1.7 The term 'INSPECTOR' or 'QUALITY SURVEYOR' means any person nominated and deputed by the purchaser or their appointed Consultants or Quality Surveillance Agency or any other person from time to time authorized by the Purchaser to act as his representative for the purpose of inspection of stores under the contract/purchase order.

2. AUTHORITY OF PERSON SIGNING THE CONTRACT ON BEHALF OF THE CONTRACTOR

The person signing the contract or the purchase order or any other document in respect of the contract or purchase order on behalf of the contractor shall be deemed to warrant that he has the authority to bind the contractor.

3. SUBLETTING OF CONTRACT OR BILLS OR ANY BENEFIT ACCRUING THEREFROM

- 3.1 The Contractor shall not sublet, transfer or assign the Contract or any part thereof or bills or any other benefits, accruing therefrom or under the contract without the prior written consent of the Purchaser (All Sub-contractors are required to be appraised and approved by the Purchaser before placement of orders by the Contractor/Supplier). However, such consent shall not be unreasonably withheld by the Purchaser, if such stores are not normally manufactured by the Contractor, such assignment or subletting shall not relieve the Contractor from any contractual obligation or responsibility under the Contract.
- 3.2 Any breach of this condition shall entitle the Purchaser to cancel the Contract or any part thereof and to purchase from other sources at the risk and cost of the Contractor and shall recover from the Contractor damages arising from such cancellations.
- 3.3 In case the Contractor sublets, transfers or assigns any part of the Contract with the prior written consent of the Purchaser, all payments to the Sub-Contractor shall be the responsibility of the Contractor and any requests from such sub-Contractor shall not be entertained by the Purchaser.

4. SECURITY DEPOSIT

- 4.1 On acceptance of tender, the Contractor shall at the option of the Purchaser and within the period specified by him, submit a Bank Guarantee from SBI or any one of the nationalized banks or reputed private banks, viz. AXIS Bank, ICICI Bank, IDBI Bank and HDFC Bank towards Security Deposit not exceeding 10% (ten percent) of the tendered value of the contract/purchase order valid till at least 2 months beyond the acceptance date of the material, as the Purchaser shall specify.
- 4.2 If the Contractor is called upon by the Purchaser to submit Security Deposit and the contractor fails to provide the same within the period specified such failure shall constitute a breach of the Contract and the Purchaser shall be entitled to make other arrangements for the repurchase of the stores contracted for at the risk and expenses of the Contractor in terms of clause 9.2.4 hereof and/or recover from the Contractor damages arising from such cancellation. No claim shall lie against the purchaser either in respect of interest if any due on Security Deposit or depreciation in value.
- 4.3 Offers wherein contractors declined to submit Security Deposit are liable to be rejected.

5. DRAWINGS & SPECIFICATIONS

- 5.1 The drawings and specifications are intended to be complementary and to provide for an comprise everything necessary for the completion of supply. Any material shown on the drawing even if not particularly described in specifications or vice versa is to be supplied by the Contractor as if it were both shown and specified.

- 5.2 Should any discrepancy be noted in the drawings and/or specifications and should any interpretation of the same be required, the matter shall be referred to the Purchaser for clarification which shall be binding upon the contractor. Otherwise, the contractor shall assume responsibility for the interpretation of the drawings and specifications including interpretation by his sub-contractors.
- 5.3 Should any difference or dispute arise with regard to the true intent and meaning of drawings or specification or should any portion of the same be obscure or capable of more than one interpretation, the same shall be decided by the Purchaser whose decision shall be final.
- 5.4 All lettering on the drawings is to be considered as part of the specification and contract. In all cases figured dimensions are to be followed rather than those indicated by scale. Large scale drawings will take precedence over small scale drawings.
- 5.5 The contractor's drawings shall, when approved by the Purchaser, be deemed to be included in the list of drawings which form part of the contract. The Contractor shall not proceed with fabrication until all drawings associated therewith have been duly approved by the Purchaser.
- 5.6 The Contractor shall be responsible for and shall pay for any alterations of the stores and shall indemnify the Purchaser for any consequential expenditure incurred by the Purchaser due to any discrepancies, errors, omissions in the drawings or other particulars supplied by him whether such drawings or specifications have been approved by the Purchaser or not, provided that such discrepancies, errors or omissions be not due to inaccurate information or specifications furnished to the contractor on behalf of the Purchaser.
- 5.7 **General Warranty**
- 5.7.1 The stores supplied by the contractor under the contract shall be of best quality and workmanship. The contractor shall supply the stores in accordance with the contract specifications unless any deviation has been expressly specified in the contract and any amendments agreed thereto.
- 5.7.2 The contractor's offer to supply stores in accordance with the tender specifications shall be deemed to be in admission on his part that he has fully acquainted himself with the details thereof and no claim shall lie against the Purchaser on the ground that the contractor did not examine or acquaint himself fully with the tender specifications.
- 5.8 **Contractor's Liability for Defective Stores**
- 5.8.1 For a period of twelve months after the stores have been accepted by Purchaser the Contractor shall be responsible for any defects that may be discovered therein notwithstanding that such defects could have been discovered at the time of inspection or any defects therein are found to have developed under proper use, arising from faulty materials, design or workmanship and the Contractor shall remedy all such defects as aforesaid at his own cost provided he is called upon within a period of 14 months from the date of acceptance thereof to do

so, by the Purchaser who shall state in writing in what respect the goods are faulty and further if in the opinion of the Purchaser the defects are of such a nature that it is necessary to replace or renew any defective stores, such replacement or renewal shall be made by the Contractor without any extra costs to the Purchaser, provided notice informing the Contractor of the defect is given by the Purchaser within the said period of 14 months. The decision of the Purchaser notwithstanding any prior approval or acceptance of the Inspector as to whether or not the stores delivered are defective or any defect has developed within the said period of twelve months or as to whether the nature of defects renewal or replacement shall be final conclusive and binding on the Contractor.

6. ALTERATIONS

- 6.1 The Purchaser may, from time to time, make changes in the drawings specifications and issue additional instructions without altering the purchase order in any manner provided that no changes shall have been ordered which materially alter the character and scope of the supply under the contract.
- 6.2 It shall be lawful for the parties to the contract to alter by mutual consent at any time and from time to time the drawings and specifications and as from the dates specified by him stores to be supplied shall be in accordance with such altered drawings and specifications provided that if any such alterations involve increase or decrease in the cost of or in the period required for production, a revision of the contract price and/or the period prescribed for delivery shall be made by mutual agreement in respect of the stores to which the alteration applies. In all other respects, the contract shall remain unaltered.

7. SAMPLES

- 7.1 Samples submitted for any reason shall be supplied without charge and freight paid without any obligation of the Purchaser as regards safe custody or safe-return thereof. All samples submitted must be clearly labelled with the Contractor's name and address and tender number. If the Contractor submits the sample with his tender the same shall not govern the standard of supply except when it has been specifically stated in the Purchase Order that it is accepted instead of any sealed pattern. Should certified samples be lent to the Contractor by the Purchaser, the Contractor is responsible for the return in perfect order of all certified samples with the labels intact.

8. PACKING

- 8.1 The contractor shall be held responsible for the stores being sufficiently and properly packed for transport by rail, road, sea or air so as to ensure their being free from any loss or damages on arrival at their destination. The packing and marking of packages shall be done by and at the expenses of the Contractor. Each package shall contain a Packing

Note quoting Purchase Order number and date and showing its contents in detail.

- 8.2 Unless otherwise provided in the contract all containers (including packing cases, boxes, tins, drums and wrappings) in which the stores are supplied by the contractor shall be considered as property of the Purchaser and their cost as having been included in the contract price.

9. DELIVERY:

9.1 TIME FOR AND DATE OF DELIVERY, THE ESSENCE OF THE CONTRACT:

The time for and the date of delivery of the stores stipulated in the purchase order/contract shall be deemed to be of the essence of the contract and delivery must be completed not later than the date/dates stipulated.

9.2 EXTENSION OF DELIVERY SCHEDULE

- 9.2.1 If any delay in delivery shall have arisen from any cause such as strike, Lock-outs, fire, accidents, riot or the like which the purchaser may admit as reasonable ground for grant of extension of delivery schedule, the purchaser will allow such additional period for the purpose as he may consider necessary taking the circumstances into consideration.
- 9.2.2 If the contractor fails to deliver the stores or any instalment or part thereof within the period fixed for such delivery or such additional period allowed by the purchaser in accordance with foregoing paragraphs or any time before the expiry of such period repudiates the contract, the Purchaser may without prejudice to the rights of the purchaser.
- 9.2.3 Recover from the contractor as Liquidated Damages and not by way of penalty as detailed under clause No.222 given herein below for any stores which the contractor has failed to deliver within the period fixed for delivery in the contract or such additional period as mentioned in paragraph 9.2.1. during which the delivery of such stores, may be in arrears where delivery thereof is accepted after expiry of the aforesaid period. (For the purpose of computing the damages for delayed supplies under the clause, the cost of the entire plant/machinery/equipment/instrument will be taken into consideration if the plant/machinery/equipment/instrument cannot be put to the intended use for want of delayed portion of supply).
- 9.2.4 Purchase or authorise the purchase elsewhere without notice to the contractor, on account and at the risk of the contractor of the stores not so delivered or others of a similar description (where stores exactly complying with the contract specification are not in the opinion of the Purchaser, which opinion shall be final, readily procurable) without cancelling the contract in respect of the portion instrument not yet due of delivery, OR
- 9.2.5 Cancel the contract or portion thereof and if so desired purchase or authorise purchase of the stores not so delivered or others of a similar description (where stores exactly complying with the contract specification are not in the opinion of the Purchaser, which opinion shall be final, readily procurable) at the risk and cost of the contractor, if the contractor had defaulted in the performance of the original contract, the purchaser shall have the right to ignore his offer in response to risk purchase enquiry even though the lowest.

- 9.2.6 Where action is taken under sub-clause 9.2.4 or sub-clause 9.2.5 above the contractor shall be liable for any loss which the purchaser may sustain on that account provided that the repurchase, or if there is an agreement to repurchase then such agreement, is made within a reasonable period from the date of such failure, depending upon the nature / merit of the purchase and in case of repudiation of the contract before the expiry of the aforesaid period of delivery, shall not be entitled to any gain on such purchase and the manner and method of such purchase shall be in the entire discretion of the Purchaser. It shall not be necessary for the purchaser to serve a notice of such purchase on the contractor.

10. INSPECTION

- 10.1 The contractor shall be responsible for and perform all inspection and testing required in accordance with the contract/purchase order and specifications included herewith.
- 10.2 The Purchaser may at his option depute his representative for Inspection of the stores to be supplied under the contract or authorize and nominate a Quality Surveillance Agency of his choice for the purpose hereinafter called, in either case, the inspection.
- 10.3 The contractor shall give notice of readiness for inspection to the Inspector (deputed under clause 10.2 above) so that the Inspector can be present at the requisite time. In such an event delivery shall not be effected until an authorization or shipping release is obtained from the Purchaser's Inspector.
- 10.4 The contractor shall allow reasonable facility and free access to his work/factory and records to the inspector for the purpose of inspection or for ascertaining the progress of delivery under the contract.

11. RECTIFICATION AND REPLACEMENT OF DEFECTIVE STORES

- 11.1 If the inspector find that the contractor has executed any unsound or imperfect work, the inspector shall notify such defects to the contractor and the contractor on receiving the details of such defects or deficiency, shall at his own expenses, within seven days or otherwise within such time as may be mutually agreed upon as reasonably necessary, proceed to alter, reconstruct or remanufacture the stores to the requisite standard and specifications as called for by the tender specification.

12. INSPECTION AND REJECTION

- 12.1 **Inspection and Rejection:** The stores shall be tendered by the Contractor for inspection at such places as may be specified by the Inspector, at the Contractor's own risk, expenses and costs and shall lie at such places of inspection at the risk of the Contractor and the stores will be subject to inspection and test as may be considered necessary by the inspector and his decision as regards rejection of goods shall be final and binding on the Contractor. If any goods are rejected as aforesaid, then without prejudice to the foregoing provision, the Purchaser shall be at liberty to
- 12.1.1 Allow the Contractor to re submit without prejudice to the Purchaser's right to claim and recover Liquidated damages as provided in clause 9.2.3 hereof, stores in replacement of those rejected within a time specified by the Purchaser (which time shall be essence of the contract), the contractor bearing the

- cost of freight for such replacement without being entitled to any extra payment, or
- 12.1.2 Buy the quantity of stores rejected or others of a similar nature elsewhere at the risk and cost of the Contractor in accordance with the provisions contained in second paragraph of clause 9.2.4 thereof without effecting the Contractor's liability as regards the supply of any further consignments due under the Contract, or
- 12.1.3 Terminate the Contract and recover from the Contractor the loss Purchaser thereby incurred
- 12.2 **Removal of rejection:** Any stores submitted for inspection and rejected by the Inspector must be removed by the Contractor within fourteen days from the date of receipt of intimation of rejection, provided that in the case of dangerous infected or perishable stores, the Inspector (whose decision shall be final) shall notify the Contractor to remove such stores within 48 hours of receipt of intimation of rejection and it shall be the duty of the Contractor to remove them accordingly. Such rejected stores shall lie at the Contractor's risk from the time of such rejection and if not removed within the aforementioned time, the Purchaser shall have the right either to return the rejected stores to the Contractor at the Contractor's risk by such mode of transport as Purchaser may select or to dispose off or segregate such stores as he thinks fit at the Contractor's risk and on his accounts and to appropriate such portion of the proceeds as may be necessary to cover any loss or expenses incurred by the Purchaser in connection with the said sale. Freight to destination of stores rejected after examination at destination shall be recoverable from the Contractor at the Tariff Rate.
- 12.3 **Test Certificate and Guarantees:** Test Certificate Guarantees, if required by the Inspector shall be obtained and furnished by the Contractor free of costs.

13. RECOVERY OF SUMS DUE

- 13.1 Whenever any claim for payment of, whether liquidated or not, moneys arises out of or under this contract against the Contractor the Purchaser shall be entitled to recover sum by appropriating, in part or whole, by encashing the Bank Guarantee submitted towards Security deposit by the Contractor, if a Security Deposit is taken against the Contract. In the event of the security being insufficient or no Security Deposit has been taken from the Contractor then the balance or the total sum or which at any time hereafter may become due to the Contractor under this or any other contract with the Purchaser, should this sum be not sufficient to cover the full amount recoverable, the Contractor shall pay to the Purchaser on demand the remaining balance due. Similarly, if the Purchaser has or makes any claim, 'whether liquidated or not against the Contractor under any other contract with the Purchaser the payment of all moneys payable under the contract to the contractor including the security deposit shall be withheld till such claims of the Purchaser are finally adjudicated upon and paid by the Contractor.
- 13.2 All demurrage, wharfage and allied expenses incurred by the Purchaser, if any, due to delayed clearance of Stores in view of non receipt, incomplete or delayed receipt of documents by the Purchaser, shall be recovered from the payment due to the Contractor.

14. BAR/PERT CHART

- 14.1 The contractor at the discretion of the Purchaser shall submit the BAR/PERT chart indicating various activities from the date of purchase order to handing over of the stores.

15. PERFORMANCE BANK GUARANTEE

- 15.1 In the event of acceptance of the offer in respect of plant, machinery, equipment, instrument, etc. the tenderer will be required to submit a performance bank guarantee for 10% of the total value of the stores inclusive of all statutory levies and other charges admitted in the contract, from SBI/any nationalized bank or private sector banks, namely, ICICI Bank, IDBI Bank, HDFC Bank and AXIS Bank, on a non-judicial stamp paper of appropriate value valid till 2 months beyond the expiry date of warranty period as per the Purchaser's format towards satisfactory performance of the plant, machinery, equipment, instrument, etc. during the warranty period. In case of bids in currency other than INR performance bank guarantee shall be furnished from any bank of international repute.
- 15.2 In case of non-submission of performance bank guarantee by the Contractor, an amount equivalent to 10% of the total value of the stores and other charges admitted in the contract will be retained by the purchaser till the expiry of the warranty period of the stores.
- 15.3 Offers of the tenders who are not agreeable to furnish performance bank guarantee or retaining of an equivalent amount by the purchaser as per clause No.15.1 and 15.2 above, are likely to be rejected.

16. PERMIT AND LICENCES

- 16.1 The contractor shall secure and pay all licenses and permit at his end which he may be required to comply with all laws ordinances and regulations of the public authorities in connection with the performance of his obligations under the contract. The contractor shall be responsible for all damages and shall indemnify and save the purchaser harmless from against all claims for damages and liability which may arise out of the failure of the contractors to secure and pay for any such licenses and permits or to comply fully which any and all applicable laws ordinances and regulations.

17. PATENTS & PATENT RIGHTS INDEMNIFICATION

- 17.1 The Contractor shall indemnify and keep indemnified the Purchaser from and against any and all claims, actions, costs, charges and expenses arising from or for infringement of patent rights, copy right or other protected rights, of any design plans, diagrams, drawings in respect of the stores supplied by the contractors or any of the manufacturing methods or process adopted by contractor for the stores supplied under the contract.
- 17.2 In the event of any claim being made or action being taken against the purchaser in respect of the matter referred to clause 17.1 above, the contractor shall promptly be notified thereof and he shall at his own expense, conduct all negotiations for the settlement of the same and any litigation that may arise therefrom.
- 17.3 In the event of any designs, drawing, plans or diagrams or any manufacturing methods or process furnished by the contractor constituting infringement of patent or any other protected rights and use thereof is restrained, the contractor shall procure for Purchaser, at

no cost to the latter, the rights to continue using the same or to the extent it is possible to replace the same so as to avoid such infringement and subject to approval by the Purchaser or modify them so that they become non-infringing, but such modifications shall otherwise be to the entire satisfaction of the Purchaser.

17.4 The provision of the clause remains effective and binding upon the Contractor even after the completion, expiration or termination of the contract.

18. LAW GOVERNING THE CONTRACT

18.1 This Contract shall be governed by the laws of India for the time being in force. The marking of all stores supplied must comply with the requirements of India Acts relating to Merchandise Marks and all the rules made under such Acts.

19. JURISDICTION

19.1 The Courts within the local limits (i.e. Gandhinagar) of whose jurisdiction the place from which the purchase order is issued is situation only shall, subject to Arbitration Clause, have jurisdiction to deal with and decide any matter out of this Purchase Order/Contract.

20. SETTLEMENT OF DISPUTES

20.1 The Purchaser and the Contractor shall make every effort to resolve amicably by direct informal negotiation any disagreement or dispute arising between them under or in connection with the Contract.

20.2 If the parties have failed to resolve their dispute or difference by such mutual consultation, then either the Purchaser or the Supplier may give notice to the other party of its intention to commence arbitration, as hereinafter provided, as to the matter in dispute, and no arbitration in respect of this matter may be commenced unless such notice is given. Any dispute or difference in respect of which a notice of intention to commence arbitration has been given in accordance with this Clause shall be finally settled by arbitration. Arbitration may be commenced prior to or after delivery of the Goods under the Contract.

21. ARBITRATION

21.1.1 In the event of any dispute or difference arising out or of in connection with any of the terms and conditions of the Purchase Order/Contract, the matter shall be referred to the Director, IPR for settlement. In case the parties to the Purchase Order are not in a position to settle the dispute mutually, the matter shall be referred to a Sole Arbitrator to be appointed in accordance with the Arbitration & Reconciliation Act, 1996 & Arbitration and Conciliation (Amendment) Act, 2015 as amended time to time.

22. LIQUIDATED DAMAGES

22.1 As per Standard Terms & conditions, the Purchaser reserves the right to levy the Liquidated Damages, for delay in supply beyond the contractual delivery date at the rate of half percent (0.5 percent) of the total Contract price (Basic price) for each calendar week of delay. The total liquidated damages shall not exceed five percent (5%) of the contract price (Basic price). Stores/Goods will be deemed to have been delivered only when all its component parts are also delivered. If certain

components are not delivered in time, the Stores/Goods will be considered as delayed until such time as the missing parts are delivered.

- 22.2 Where the Contract entered into is a composite one with supply cum erection and installation/commissioning activities and the completion of erection and installation/commissioning is delayed irrespective of the fact that whether supply of material has been made within the original delivery period, the contract is to be considered as a whole and Liquidated Damages will be recovered on the total contract value.

23. EXERCISING THE RIGHTS AND POWERS OF THE PURCHASER

- 23.1 All the rights, discretions and powers of the Purchase under the contract shall be exercisable by and all notices on behalf of the Purchaser shall be given by the Purchase Officer and any reference to the opinion of the Purchaser in the terms and conditions contained in these General Conditions of all Contracts shall mean and be construed as reference to the opinion of any of the persons mentioned in this clause.

24. TRAINING

- 24.1 The successful tenderer shall, if required by the Purchaser, provide facilities for the practical training of Purchaser's engineering or technical personnel for their active association on the manufacturing process throughout the manufacturing period of the Contract/stores, number of such personnel to be mutually agreed upon. If demanded by the Purchaser, such training shall be conducted at Purchaser's site by the Contractor free of charge. The duration of training shall be mutually decided upon by the Purchaser and the Contractor.

25. RISK PURCHASE

- 25.1 In the event supplier fails to fulfill the contractual obligations as per the terms and conditions of the Contract, the Purchaser has an option of completing the Contract at the risk and expenses of the Contractor. While initiating risk purchase at the risk and expenses of the supplier, the Purchaser must satisfy himself that the supplier has failed to deliver and he has been given all the opportunities as per the Contract to execute the Contract and also adequate and proper notice. Wherever risk purchase is resorted to, the supplier is liable to pay the additional amount spent by the government, if any as compared to contracted amount. All the factors including the method of recovering such amount should also be considered while taking a decision to invoke the risk purchase.

26. LIEN IN RESPECT OF CLAIMS IN OTHER CONTRACTS

- 26.1 Any sum of money due and payable to the Contractor under any contract may be withheld or retained by way of lien by the purchaser or any other person or persons contracting through the Director, IPR against any claim of the Purchaser or such other person or persons in respect of payment of a sum of money arising out of or under any other contract made by the contractor with the Purchaser or with other such person or persons.
- 26.2 It is an agreed term of the contract that the sum of money so withheld or retained under this clause by the Purchaser will be kept withheld or retained as such by purchaser till this claim arising out of in the same

contract or any other contract is either mutually settled or determined by the arbitrator, and that the contractor shall have no claim for interest or damages whatsoever on this account or on any other ground in respect of any sum of money withheld or retained under this clause and duly notified as such to the contractor.

SPECIAL CONDITIONS OF CONTRACT GOVERNING SUPPLIES OF PLANT AND MACHINERY

In addition to the General Conditions of Contract hereinbefore set out the following special conditions shall apply to contracts for the supply of Plant and Machinery and manufactured equipment. These Special Conditions where they differ from the General Conditions shall over-ride the later.

27. DEFINITION OF PLANT

27.1 The word "PLANT" wherever, appears in these "Special Conditions of Contract governing supplies of Plants and Machinery" shall mean all machinery, plants, equipment or parts thereof or what the Contractor agrees to supply under contract as specified in the Purchase Order.

28. MISTAKES IN DRAWING

28.1 The Contractor shall be responsible for and shall pay for an alterations of the works due to any discrepancies, errors or omissions in the drawings or other particulars supplied by him whether such drawings or particulars have been approved by the Purchaser or not.

29. RESPONSIBILITY FOR COMPLETENESS

29.1 All fittings or accessories which may not be specifically mentioned in the specification but for which are usual or necessary, are to be provided by the Contractor without extra charge and the plant must be complete in all respects.

30. REJECTION OF DEFECTIVE PLANT

30.1 If the completed plant or any portion thereof before it is finally accepted is found to be defective or fails to fulfill the requirements of the contract, the Purchaser shall give the Contractor notice setting forth with the details of such defects or failure and the contractor shall forthwith rectify the defective plant or alter the same to make comply with the requirement of the contract. Should the contractors fail to do so within a reasonable time the Purchaser may reject and replace at the cost of the Contractor, the whole or any portion of the Plant as the case may be, which is defective or fails to fulfill the requirement of the contract. Such replacement shall be carried out by the Purchaser within a reasonable time and at reasonable price and where reasonably possible to the same specifications and under competitive conditions. The Contractor shall be liable to pay to the Purchaser the extra cost, if any, of such replacement delivered and or erected as provided for in the contract such extra cost being the difference between the price paid by the Purchaser under the provisions above mentioned for such replacement and the contract price for them. Contractor shall refund to Purchaser any sum paid by the Purchaser to the Contractor in respect of such defective plant.

31. INSPECTION AND FINAL TESTS

31.1 All tests necessary to ensure that the plant complies with the particulars and guarantees shall be carried out at such place or places as may be determined by the inspector. Should, however, it be necessary for the final tests as to performance or guarantees to be held over until the Plant is erected at site they shall be carried out within

one month of completion of erection.

32. TRANSPORT AND RESPONSIBILITY FOR BREAKAGES EN-ROUTE

32.1 Unless otherwise specified the Purchaser will take delivery of the plant from the place named in the purchase order but the contractor will be responsible for any damage which may be caused to the Plant during transit to the site of erection thereof.

33. ERECTION AND COMMISSIONING

33.1 In all cases where contracts provide for supervision of erection and commissioning or for test at the Purchaser's premises the Purchaser except where otherwise specified, shall provide free of charge, such labour, materials, fuels, stores, apparatus and instruments as may be required from time to time and as may reasonably be demanded by the contractor to carryout efficiently such supervision of erection and commissioning and for the requisite test. In case of contracts requiring electricity for the completion of erection, commissioning and testing at site, such electricity shall be supplied free to the contractor.

33.2 Action by the Purchaser under the clause shall not relieve the contractor of his warranty obligations under the contract.

34. WARRANTY

34.1 The contractor warrants that stores to be supplied under the contract shall be free from all defects and faults in materials, workmanship and manufacture and shall be of the highest grade and consistent with the established and generally accepted standards for stores of the types under the contract in full conformity with the specifications, drawings or samples, if any and shall if operable, operate properly. This warranty shall expire (except in respect of complaints notified to the contractor prior to such date) twelve months after the date of receipt of the last lot of stores under the contract at the ultimate destination stipulated in the contract.

34.2 For a period of twelve calendar months after the plant/machinery/equipment/instruments has been put into operation (or a suitable mutually agreed longer period to be reckoned from the date of last major shipment depending upon the nature of the plant/machinery/equipment/instrument) the Contractor shall be responsible for any defects that may develop under conditions provided for the contract and under proper use, arising from the faulty materials, design or workmanship in the plant or from faulty erection of the plant by the Contractor, but otherwise and shall rectify such defects at his own cost when called upon to do so by the Purchaser who shall state in writing such defects.

34.3 If it becomes necessary for the Contractor to replace or renew any defective portions of the plant for purpose of rectification under this clause, the provisions of this clause shall apply to the portions of the plant so replaced or renewed under the expiration of six months from the date of such replacement or renewal or until the end of the above mentioned period of twelve months whichever may be the later. If any defects not rectified within reasonable time, the purchaser may proceed to get the work done at contractor's risk and expenses but without prejudice to any other rights which the Purchaser may have against the Contractor in respect of such defects as provided in clause 9.2.4 or 9.2.5.

- 34.4 All inspections adjustments, replacements or renewals carried out Contractor during the warranty period shall be subject to the same conditions as in the contract.
- 34.5 Contractor shall, spare parts of equipment before going out of production, give adequate advance notice to the purchaser so that the latter may order requirement of spares in one lot if so desires.
- 34.6 The contractor shall further guarantee that if spare parts go out of production, will make available blue prints, drawings of spare parts and specifications of material at no cost to the Purchaser, if and when required in connection with the equipment to enable Purchaser to fabricate or procure spare parts from other sources.
- 34.7 The provision of this clause shall remain effective and binding upon the Contractor even after the completion or expiration of the contract and till the plant/machinery/equipment supplied under the contract is in use by the Purchaser.

35. MODE OF PAYMENT

- 35.1 Unless otherwise agreed to in writing between the Purchaser and the Contractor, payment for the delivery of the material will be made as follows.
- Within 30 days from the date of final acceptance and on receipt of Performance Bank guarantee for 10% of the contract value amount from SBI/nationalized banks or any one of the scheduled banks mentioned in the bracket (Axis Bank, HDFC Bank, ICICI Bank and IDBI Bank) valid through out the guarantee period mentioned in the contract/purchase order.**
- 35.1.1 In case any of the vendors seek advance or progressive payment prior to delivery of the material, such requests can be considered only in exceptional cases of large value items, in which case the vendor will be required to furnish a bank guarantee for an equivalent amount of the advance/progressive payment sought for, valid till the execution of the contract. The bank guarantee shall be got executed as per the Purchaser's format from the State Bank of India (SBI)/nationalized banks or any one of the scheduled banks mentioned in the bracket (Axis Bank, HDFC Bank, ICICI Bank and IDBI Bank).
- 35.1.2 Besides, the offers of the vendors seeking advance/progressive payment will be evaluated by loading 12% interest charges per annum on the amount of advance desired up to the delivery period quoted.
- 35.1.3 In case any of the vendors seek pro-rata payment for the stores to be supplied they should clearly mention in their offer the maximum number of installments of supply. However, such installment delivery and pro-rata payment will be considered only in respect of contract involving large value and sizeable quantity of the item and the maximum number of installments shall be normally restricted to four. Acceptance or otherwise of this condition is reserved by the purchaser.
- 35.1.4 **Bank Charges:** All bank charges to be borne by the Contractor/Supplier.
- 35.1.5 No correspondence will be entertained within 30 days from the date of receipt of material and bills, whichever is later.
- 35.1.6 **Interest for delay in supply beyond the contractual delivery date:** Wherever advance payments are sought for by the contractor and

admitted in the contract, against Bank Guarantee for equivalent amount, in the event of any delay in supply beyond the contractual delivery date for reasons attributable to the contractor, interest charges @ 12% shall be levied for the period beyond the contractual delivery date, on the amount of balance advance payment to be adjusted.

36. DELAY IN ERECTION

36.1 Wherever erection of a plant or machinery is the responsibility of the Contractor as a term of the contract and in case the Contractor fails to carry out the erection as and when called upon as to do within the period specified by the Purchaser, the Purchaser shall have right to get the erection done through any source of his choice. In such an event, the contractor shall be liable to bear any additional expenditure that the Purchaser may incur towards erection. The Contractor shall, however, not be entitled to any gain due to such an action by the Purchaser.

SECTION 'C'

**TECHNICAL SPECIFICATIONS
OF
STORES AND DRAWINGS**

Please refer tender document

SECTION 'D'

FORMAT FOR SUBMISSION OF PART-II (PRICE)

Please refer tender document

TENDER FORM
INSTITUTE FOR PLASMA RESEARCH
(An Aided Institute of
Department of Atomic Energy, Government of India)
Near Indira Bridge; Bhat; Gandhinagar-382428; India

Following terms are replaced in our Form for Tender No.IPR/TN/PUR/TPT/18-19/46 dated 9/1/2019.

- 1) Sr.No.3.1 (Section-A) under heading “Earnest Money Deposit (EMD)” of Form No.IPR-LP-ET-02.V5 (Terms and Conditions) is replaced with the following:
The Tenderer shall submit, as part of its bid, interest free Earnest Money Deposit (EMD) for an amount as specified in the Tender Notice. EMD shall be submitted by way of Demand Draft from **SBI/nationalized banks or any one of the scheduled banks mentioned in the bracket (Axis Bank, HDFC Bank, ICICI Bank and IDBI Bank)** issued in favour of **"Institute for Plasma Research"** and payable at **Ahmedabad. Tender received without EMD will be rejected at the discretion of IPR.**
(Copy of Demand Draft to be uploaded with the quotation, Original DD should be sent to IPR on or before the specified closing date and time)
- 2) Sr.No.3.4 (Section-A) under heading “Earnest Money Deposit (EMD)” of Form No.IPR-LP-ET-02.V5 (Terms and Conditions) is replaced with the following:
Exemption from payment of EMD: The firms registered with DGS&D, NSIC, DPS or Micro & Small Enterprises (MSEs) which are actual producers/manufacturers of tendered items are exempted from payment of EMD provided valid registration certificate is uploaded along with the offer.
- 3) Sr.No.18 (Section-A) under heading “Statutory Levies such as Customs Duty, Goods and Service Tax” of Form No.IPR-LP-ET-02.V5 (Terms and Conditions) is replaced with the following:
Clause Nos.18.1, 18.2, 18.3 and its sub-clauses deleted from Form No: IPR-LP-ET-02.V5.
- 4) Sr.No.22 (Section-A) under heading “Submission of Drawings” of Form No.IPR-LP-ET-02.V5 (Terms and Conditions) is replaced with the following:
Submission of Drawings: The tenderer shall furnish all drawings pertaining to the plant/machinery/ equipment/component to the Purchaser along with the tender for correct understanding and appreciation of the tender in quadruplicate. Besides, tenderers should also furnish general arrangement, schematic and such other drawings prescribed by the Purchaser within 30 days from the date of receipt of Purchase Order for approval. Such drawings should be furnished along with Part-I (Techno-Commercial) of the tender. Tenderer’s drawing will form part of the purchase order/contract only after these are approved by the Purchaser.

- 5) Sr.No.31 (Section-A) under heading “Delivery” of Form No.IPR-LP-ET-02.V5 (Terms and Conditions) is replaced with the following:

Delivery: Tenderer should note that no tender will be considered by the Purchaser unless the Tenderer can meet the delivery schedule specified by the Purchaser. All equipments/machinery/plant/component covered by this tender document should be supplied & commissioned at IPR within 8 months from the date of approval of design documents (For more details, please refer to Section 7.1 of Section-C. The prices quoted by the tenderer should include all charges involved for direct and safe delivery of the items by Road to the project site of the Purchaser. If a tenderer so desires/separate lumpsum charges for transportation and safe delivery to Purchaser’s site could be furnished. Purchaser will neither undertake responsibility for transit insurance nor pay for it separately. No other, delivery term will be accepted by the Purchaser

- 6) Sr. No. 35 (Section-B) under heading Mode of Payment of “General Conditions of Contract” of Form No.IPR-LP-ET-02.V5 (Terms and Conditions) is replaced with the following:

Payment: Unless otherwise agreed to in writing between the Purchaser and the Contractor, payment for the delivery of the tendered items, will be made as follows.

- a) 80% of supply portion (i.e. items Sr.No.1,3 & 5 in the price bid) + 100% of all other charges will be paid after receipt of material at IPR site and its verification by IPR representative and on receipt of invoice in triplicate.
- b) Balance 20% of supply portion (i.e. items Sr.No.1,3 & 5 in the price bid) along with 100% installation and Test Jig charges (items Sr. No.2, 4 & 6 of price bid) will be paid within 30 days from the date of acceptance and on receipt of Performance Bank Guarantee for 10% of the order value from SBI/nationalized banks or any one of the scheduled banks mentioned in the bracket (Axis Bank, HDFC Bank, ICICI Bank and IDBI Bank) valid throughout the warranty period and on receipt of final invoice.

Following terms is **added to** our Form No. IPR-LP-ET-02.V5 for Tender No. No.IPR/TN/ PUR/TPT/18-19/xx dated 27/12/2018.

- a) **TDS as per CGST Act:** As per the provisions mentioned under Section No. 51 of the CGST Act 2017, TDS @ 2% (IGST 2% or CGST 1% and SGST 1%) will be deducted while making payment to the suppliers where total value of the purchase order/contracts/work orders exceeds Rs.2.5 Lakhs. Necessary TDS Certificate will be issued to the supplier after TDS deduction.

IMPORTANT NOTE:

[1] QUOTATIONS ARE INVITED IN INDIAN CURRENCY ONLY

[2] QUOTATIONS RECEIVED OTHER THAN “INR” QUOTE SHALL SUMMARILY BE REJECTED.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

**Tender No: IPR/TN/PUR/TPT/ET/18-19/46 DATED
9/1/2019**

Section-C

TECHNICAL SPECIFICATION

FOR

**300 kVA, 400 V, 400 Hz Three Phase, Sine Wave Solid State Regulated
DC to AC Converter (Inverter) units and Master Control Panel**



**INSTITUTE FOR PLASMA RESEARCH
BHAT, GANDHINAGAR – 382 428
GUJARAT, INDIA**



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

TABLE OF CONTENT

1. Scope of Supply
2. Scope of Work
3. Application Description
4. Technical Specifications
5. Technical Requirements
6. Acceptance Tests
7. Contract Management.

Annexure-I: Application, Functional and Layout Block Diagram of 500 kV UHVPS System

Annexure-II: Technical Compliance



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

1. SCOPE OF SUPPLY :

- a) Scope of supply includes Design, Engineering, Manufacture, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (*three*) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) and 1 (*one*) unit of Master Control Panel along with accessories and recommended spares at Institute for Plasma Research (IPR), Gandhinagar as per the technical specifications (including annexures) mentioned in this tender document.
- b) The scope of the bidder shall be deemed to include all such items which although are not specifically mentioned in the tender documents and/or in bidder's proposal but are needed to make the system complete in all respects for its safe, reliable, efficient and trouble free operation and the same shall be supplied and erected unless otherwise specifically excluded.
- c) Bidders shall confirm total compliance to the specification without any deviation from the technical and quality assurance requirements stipulated in this document.

2. SCOPE OF WORK:

The scope of works includes, but not limited to, the following main tasks:

- a) Design of regulated inverter modules and master control panel as per technical specifications.
- b) Submission of detailed engineering design report/documents, drawings, quality plan, manufacturing schedule, Factory Acceptance Tests (FAT) and Site Acceptance Tests (SAT) procedures for IPR's review and approval.
- c) Material procurement, fabrication, and assembly of the inverter modules and master control panel as per functional requirements.
- d) Arrange the stage wise inspections as per approved Quality Plan and implementation of modifications (if any).
- e) Perform the Factory Acceptance Tests (FAT) as per approved acceptance test procedure complying the specifications as specified.
- f) Upon receipt of dispatch clearance note from IPR, Pack and Deliver the Inverter modules, Master Control Panel and recommended spare (if any) at IPR site.
- g) Installation of Inverter Modules and Master Control Panel including control system interface integration and input/output power connection (Bus-bar/Cable) at site.
- h) Perform the Site Acceptance Tests (SAT) as per approved acceptance test procedure.
- i) Provide operational and instruction manuals with full technical details.
- j) Provide training of the operation and maintenance for minimum 2 people at IPR.
- k) Provide FAT and SAT reports with all tests results, to the IPR before final acceptance.
- l) Provide technical support as per warranty clause.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

3. APPLICATION DESCRIPTION:

The 500 kV DC Ultra High Voltage Power Supply (UHVPS) System is being developed at IPR for supplying DC Power to Particle Accelerator of rating up to 500 keV / 1000 kW. The UHVPS being developed using three stage power conversion as shown in Fig.-1. The first stage regulated AC to DC Converter (Rectifier) unit will supply DC power to second stage i.e. five modules of regulated DC to AC Converters (Inverter) each rated for 300 kVA, 400 V, 400 Hz, three phase output (ONLY THREE (3) MODULES ARE IN SCOPE OF SUPPLY OF THIS TENDER) and are connected in parallel. Each inverter module will drive third stage i.e. one High Voltage AC to DC Converter (HV Rectifier) unit to produce 100 kV DC output. All five high voltage rectifier units' output will be series connected to produce 500 kV DC output. The 500 kV UHVPS will be coarse and fine regulated and controlled by first stage rectifier unit and second stage inverter units respectively.




Figure 1: General Block Diagram of 500 kV DC Ultra High Voltage Power Supply (UHVPS)

4. TECHNICAL SPECIFICATIONS:

4.1 DC/AC Converter (Inverter)

The DC/AC Converter (Inverter) modules shall be designed and supplied as per the technical specifications defined in Table-1.

Table-1: Inverter Unit Technical Specifications

Sr. No.	Parameters	IPR Requirement
1.	Site Condition	
a)	Ambient Temperature (maximum/minimum/average (annual))	47 °C / 4 °C / 35 °C
b)	Relative Humidity (maximum / minimum)	90 % / 17 %
c)	Altitude	55 meters above MSL
d)	Installation	Indoor



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

2.	Input Supply	
a)	Input Voltage	600 V DC
b)	Input voltage variation under steady state condition	$\pm 5 \%$
c)	Input voltage variation under transient state condition	$\pm 10 \%$
3.	Performance Requirement	
a)	Inverter topology (Proposed)	Suitable Multi-Level IGBT based PWM Inverter.
b)	AC output power	300 kVA
c)	AC output voltage	400 V RMS
d)	AC output frequency	400 Hz $\pm 5\%$
e)	Output voltage wave form	Sine Wave
f)	Output Power factor	0.9 (lagging) to 1.0
g)	Number of Phases	Three phase
h)	Efficiency	$\geq 95 \%$ at rated output power
i)	Total Harmonic Distortion (THD) %	$\leq 5 \%$ Output voltage
j)	Output overloading	100 % for Continuous 120 % for 60 seconds
k)	Output Voltage Control range	20% - 100 %
l)	Control accuracy	$\leq \pm 1\%$
m)	Regulation	$\pm 1\%$ for 20% - 100 % Load Variation $\pm 1\%$ for $\pm 10\%$ Input Voltage Variation
n)	Response time (in the event of external trip command)	$\leq 100 \mu\text{sec}$
o)	Type of Cooling	Forced air cooled
p)	Protection class	IP 30
q)	Protection	i. Input DC bus over and under voltage fault; ii. Output over current and over voltage fault; iii. Short circuit fault; iv. Heat Sink over temperature.
4.	Inverter Module Monitoring, Controls and Operation	
a.	Local Control Panel (may confined to each inverter module)	<ul style="list-style-type: none"> • Measurement: AC and DC Voltage and Current • Control Parameters: <ul style="list-style-type: none"> i. Set Output Voltage– Multi-turn potentiometer (lockable)/HMI for a control range of 20% - 100% having resolution of 1 V or better



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

		<ul style="list-style-type: none"> ii. Operation/ Mode Section - Local / Remote : Selector switch with keys / illuminated lamp iii. Inverter ON - Illuminated Push buttons iv. Inverter OFF/ Emergency stop – Mushroom head Push button v. Fault / Fault reset – Illuminated Push button. vi. DC ON – Illuminated Push buttons vii. DC OFF – Illuminated push button. <p>And as per Section 5.6 and Annexure-I</p>
b.	Remote integration with Master Control Panel (MCP)	<ul style="list-style-type: none"> • Interface Type: <ul style="list-style-type: none"> i. Fiber Optic • Interface signals: <ul style="list-style-type: none"> ii. All major monitoring, control and protection parameters available at Local control panel. <p>And as per Section 5.6 and Annexure -I</p>
5.	DC/AC Converter (Inverter) terminations:	
a.	Input	Suitably sized Busbar / Cable
b.	Output	Suitably sized Busbar / Cable
6.	Applicable Standards	IEC 60146 1-4

4.2 Master Control Panel:

The Master Control Panel shall be designed, developed and tested to meet the functional/operational requirements of the 500 kV UHVPS and as defined in Table - 2.

Table-2: MCP Technical Specifications

Sr. No.	Parameters	IPR Requirement
a.	Type of Controller	<ul style="list-style-type: none"> • 32 bit Digital Controller or better
b.	I/O updating cycle	<ul style="list-style-type: none"> • Refresh Processing
c.	Processing Time	<ul style="list-style-type: none"> • 10 nano seconds or better
d.	Startup time	<ul style="list-style-type: none"> • 60 sec. or better
e.	Interface (For integration of UHVPS system viz. regulated AC/DC Rectifier system, five units)	<ul style="list-style-type: none"> • Measurement: AC and DC Voltage & Current • Control Parameters:



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

	of DC/AC Inverter and HV AC/DC Rectifier system.)	<ul style="list-style-type: none"> i. Set Output Voltage reference of Inverter units and Rectifier ii. Operation/ Mode Section - Local / Remote : Status iii. Rectifier/Inverter ON iv. Rectifier/Inverter OFF/ Emergency stop v. Fault / Fault reset vi. HV DC ON vii. HV DC OFF • Remote PC) i. All major monitoring and control parameters available at Master control panel <p>And as per Section 5.6 and Annexure-I</p>
f.	<p>Interface type:</p> <ul style="list-style-type: none"> • Between Rectifier Local Control Panel and Master Control Panel; • Between Inverter Module Local Control Panel and Master Control Panel • All other external digital signals and analog signals • between Master Control Panel and Remote PC 	<ul style="list-style-type: none"> • Optical Fiber cable which includes Transmitter and Receiver unit. • Optical Fiber cable which includes Transmitter and Receiver unit. • Optical Fiber cable which includes Transmitter and Receiver unit. • Ethernet / RS-232/485

5. TECHNICAL REQUIREMENTS:

5.1 DC/AC Converter (Inverter) system:

- a) The DC / AC Converter (inverter) system will be divided into five units (3 units in scope) as shown in Fig.-2 of Annexure-I. The main purpose of each such inverter units is to produce the 400Hz alternating voltage to feed the respective step-up transformer of the ac/dc 100 kV rectifier stage.
- b) The design, engineering, manufacturing of inverter units shall comply with all technical and functional requirements mentioned in Table-1.
- c) Each individual inverter unit in general composed of DC Link Capacitors, suitable Multi level three phase Inverter Bridge and a sine filter. However bidder shall consider appropriate design topology/configuration that meets the technical and performance requirements defined in this document.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

- d) The inverter unit shall operate properly with a dc link voltage between 20 % and 100 % of the rated dc-link voltage under steady state operating condition. When the dc-link will operate at reduced voltage, also the output voltage and current will be reduced.
- e) The inverter units shall be provided with suitably rated sine filter to meet the requirement of total harmonic distortion of the output voltage.
- f) Each inverter unit shall supply the primary side of a 3-phase step-up transformer, having Diode Bridge Rectifier at the secondary side. The step-up transformer parameters if required shall be provided to successful bidder at the time of detailed engineering design. The bidder may however consider for its estimation the leakage impedance of 10% of step-up transformer.
- g) Each inverter unit shall be complete with all the devices needed to assure the proper working of the inverter itself (as, for example, snubbers and clamp networks, etc...) and protection against internal and external faults.
- h) The rating of the components and the intervention thresholds of the protection systems shall be designed to avoid any dangerous stress, in terms of voltage, current and temperature of the semiconductors.
- i) In case of inverter fault, e.g. short circuit of a component, the inverter system shall be able to limit the consequences of the fault avoiding the damage of other components, and driving the system into a safe condition. This shall be obtained by a fast detection of the fault and a fast intervention of the protection system.
- j) The response time or switch-off time of inverter unit as defined shall be less than or equal to 100 μ sec. After some tens of milliseconds, the UHVPS shall restart the normal operation.
- k) Inverter unit local controller shall regulate independently its output voltage in close loop feedback control as per the reference signals (either set at local control panel or provided by Remote or the Master Control Panel (MCP)) the regulation shall meet the accuracy and bandwidth requirements.
- l) The feedback regulation shall be based on a Proportional Integral Derivative (PID) controller. It shall be possible to set the P, I, D values and in general all relevant parameters for the operation of inverter unit in normal operating conditions and during transients. The PID values shall be configurable from Local Control Panel and MCP.
- m) The Inverter unit local controller shall allow operating the inverter system in “Remote Control” and in “Local Control”. A Remote/Local changeover facility shall be provided at Local Control panels only to switch between these two modes of operation.
- n) The Inverter module will normally operate in “Remote Control”, from MCP. However, it shall be possible to operate in “Local Control” for the purpose of testing, trouble-shooting and commissioning of the UHVPS into a dummy load.
- o) In Local control mode the inverter unit shall be operated only from its HMI and the commands from MCP shall be ignored.
- p) The bidder shall provide for each inverter unit at least the following analog measurements:



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

-
- Three line current measurements, one for each output phase
 - Three phase-to-phase output voltage measurement.
- q) The inverter units shall be designed for forced air cooling.
- r) Grounding/Earthing: The inverter unit shall have suitable grounding, which ensures safer operation of the system under normal and abnormal conditions. All the lines of power, control (analog and digital) shall be properly terminated to their respective returns. All the Inverter modules should be similar and interchangeable.
- s) The Local Control Panel of the Inverter and MCP shall be double shielded and properly grounded for protection against possible electrostatic interference caused by 500 kV equipment installed in the vicinity.

5.2 DC-Link Capacitor Banks

- a) For a proper working, the inverter units needs at the input side a capacitor bank, in order to exchange reactive energy with the load through the inverters and to limit the fluctuation of the dc-link voltage during transient energy request, as for example during fast increase and decreasing of the load.
- b) The capacitor unit and bank shall comply with IEC 61071 and be designed for continuous duty i.e. it shall be assumed that their rated voltage is permanently applied to their terminals.
- c) The capacitor bank shall be rated for a dc-link working voltage of 600 V, with a maximum variation of $\pm 10\%$ in transient conditions.
- d) The measured value of capacitance of each capacitor units shall be within $0\% / + 10\%$ of the nominal capacitance value, when corrected to the reference temperature, in dc conditions.
- e) The capacitor units shall keep their capacitance value within the specified limits during all their service life.
- f) Soft-start shall be present on the input side to alleviate turn-on stress on DC Link Capacitor charging irrespective of potentiometer position.
- g) For the capacitor banks, the supplier shall provide a means of discharging the energy followed by a shorting system which connects a short circuit across the capacitors/banks and an earthing system which connects the entire energy storage system to the local earth. All these systems (discharging, shorting, and earthing) shall be controlled by the control and interlock system and to be operated in the correct sequence. These three functions may be combined in a single switch system with mechanical and electrical interlocks for safety.
- h) A discharging circuit shall comprise a remotely operated switch and series resistor. The resistor is used to limit the current and to absorb the stored energy and its value and rating shall limit temperature rises to safe values (including for repeated discharging cycles). The discharging system shall be capable of bringing the voltage on each capacitor/bank down to a low and safe level before any shorting switches operate.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

- i) Each inverter unit shall be provided with a dedicated mechanical bypass switch, in order to permit a fast discharge of the capacitor unit or if it is requested by the protection system. A series resistor shall be included in the bypass switch to limit the fault current to a safe level. Each capacitor unit shall be provided with a dedicated voltage measurement, to be used to detect over-voltage on the dc-link and to generate the request of intervention of the bypass switch.
- j) Each capacitor unit shall be provided with all the passive devices needed to guarantee the proper working of the system, to limit the consequences of a fault, and to ensure the safety of the personnel, on the basis of the supplier experience and design choices.

5.3 Busbar and Cables

- a) The bidder shall supply, install and terminate the power connection at the terminals (in particular, five connections shall be provided one for each stage) as follows:
 - Connection between ac/dc rectifier dc-link and individual dc/ac inverter units;
 - Connection between each inverter units and respective step-up transformer of ac/dc HV stage.
- b) Due to the high current rating of dc-link at the input and ac-link (400 Hz) at the output of each inverter, the supplier can choose to use either busbars or cables. The electrical parameters of the cable/busbars (insulating voltage, sections, number of conductors, etc.) shall be defined by the supplier, under its responsibility, on the basis of the result of the design.
- c) The length of each ac and dc connection shall be worked out on the basis of the layout. In any case each link length shall not be greater than 5 meters.

5.4 Electrical:

- a) All the termination (electrical cables entries) points shall be easily accessible to reduce the complexity while operation, alteration and maintenance activities.
- b) All the current carrying parts shall be separated by physical barriers to ensure safety. All the terminals except AC earth shall be electrically isolated. Protecting fuses and Circuit-breakers/Contactors provided shall be easily accessible and properly rated to facilitate easy replacement.
- c) There should be a clear and prominent “DANGER” Marking at the terminal block.
- d) All insulated conductors except those within the confines of a PCB assembly, shall be of the suitable ratings, which are enough to withstand the maximum current and voltage during overload and/or fault/abnormal conditions.
- e) All wiring shall be neatly secured in position and adequately supported. Where cables/wires pass through the metal panel; suitable size of cable glands shall be used. All the wires and cables used shall be of low smoke fire retardant as per IS 1554 and IS 694 or IEC 61034 with



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

latest amendments and they shall be properly rated to prevent excessive heating. Proper indication on cable shall be provided for all the cables.

- f) The associated AC, DC connections, control, alarms and interface cable connecting the unit shall be connected/disconnected easily without causing any interruption in the supply and damage to load or other circuits. All live parts AC, DC, and control, alarm and monitoring cables interconnecting the units shall be easily disconnected by plugs and connectors.

5.5 Assembly and Mounting arrangement:

- a) The inverter unit enclosure shall be made up of rigid and self-supporting structure of suitable steel sheet/profiles and shall be free of sharp edges/corners. The structural strength of the unit shall be such as to withstand its ultimate mechanical load without any deformity. The base of inverter unit shall ensure uniform floor loading. The gauge of steel that is used for the fabrication of inverter unit shall not be less than 2.5 mm (minimum).
- b) Lifting facilities shall be provided by removable eyebolt located at the top of the unit or by any other means which ensure the portability. Top of the unit shall be fully covered except for ventilation and/or cable entries. The necessary arrangement for fixing the unit on the floor shall also be provided.
- c) The enclosure sides of the inverter unit shall have suitable ventilating arrangements. Each air flow vent shall be covered by a grill to prevent the entry of foreign material larger than 2.5 mm. The front and rear door (if provided shall be of hinged type and shall have proper arrangement for ventilation).
- d) The inverter units shall be designed for easy operation, maintenance and installation. The unit mounting arrangement shall be such as to provide easy access from front, rear and top for installation and maintenance activities.
- e) The inverter unit shall be made standalone with a rigid framework with bottom clearance of 100 mm.
- f) All the doors of the inverter unit shall be equipped with the cabinet locks with keys (either distinctive or same for all doors). All the doors shall be provided with neoprene rubber gasket to make the panel compartments dust proof.
- g) Cooling: Ample number of exhaust/blow fans with proper ratings should be employed; these fans should be of die-cast aluminium painted black with grills.
- h) The manufacturer shall ensure good workmanship while manufacturing/fabrication process of the inverter unit.



5.6 UHVPS Master Control System

- a) The bidder shall supply a Master Control System, named UHVPS Master Control (UHVPS-MC), for remote control, monitoring, protection, interlocking, alarm handling, alarm logging, data collection and signal conditioning of the UHVPS. The supplier's design of the UHVPS-MC shall be subjected to the approval of the IPR (purchaser).
- b) The UHVPS-MC Panel shall include all the equipment's and devices required to perform following tasks:
 - set-up all the configurable parameters for Rectifier and Inverter units viz. reference, protection threshold values for the integrated operation of the UHVPS;
 - allow the local and remote operation of the UHVPS;
 - put in place coordinated actions against internal and external faults;
 - provide all necessary interlocks to guarantee the correct operation of the system and the safety of personnel;
 - display the status of all control and protective devices of the UHVPS, including auxiliaries;
 - Provide a history of database of alarms.
 - Integration with Industrial PC (Supply of PC NOT IN THE SCOPE OF THIS Tender).
- c) The control actions of the UHVPS-MCP shall be restricted to the control of UHVPS and to the coordination of the different UHVPS sub-systems viz. Controlled Rectifier System, Inverter System, and HV Rectifier System.
- d) Control Inputs to MCP: 0-10V signals from (1a) Final DC output [external] (1b) Input rectifier DC output [external] (1c) inverter output parameters [scope of bidder]. Controlled outputs from MCP: 0-10V Signals to (2a) Input rectifier unit [external] (2b) Inverter unit [scope of bidder]. The optical fiber cable with transmitter and receiver for all signals interfacing with each sub-system mentioned above is in the scope of supply.
- e) All the UHVPS-MC devices which are at earth potential shall be installed in Master Control Panel (MCP). The associated "driver" (e.g. firing circuits, gate units, etc.) may be installed inside respective inverter unit enclosures.
- f) The MCP shall be provided with doors for easy access to all devices and equipped with fans as appropriate; and terminal blocks for cable termination.
- g) Important control signals shall be brought to BNC connectors on front panel.
- h) The structure of the UHVPS-MC shall include:
 - a Human Machine Interface (HMI);



-
- a PLC or equivalent device for the management of slow signals, alarm handling, local/remote changeover facilities and safety devices and interlocks (e.g. emergency buttons);
 - a device for exchange of data with remote operation console (e.g. Ethernet link/RS 485);
 - a system of electronic boards or devices, based on FPGAs and/or microcontrollers to manage all fast signals, protections and interlocks;
 - a system for transmitting and receiving timing and protection signals;
 - a system for transmitting and receiving measurement and reference signals.
- i) The UHVPS-MC will normally operate from Remote Operation Console (ROC). However, it shall be possible to operate MCP for the purpose of testing, trouble-shooting and commissioning of the UHVPS into a dummy load.
- j) From the MCP it shall be possible to test the functionality of all sub-systems of UHVPS.
- k) The UHVPS-MC shall control the AC / DC Converter (Rectifier) unit and the five DC/AC Inverter units. The electrical quantities to be controlled shall be the output dc-link voltage and the Inverter output Voltage.
- l) The amplitude of the ripple of the output dc voltage varies with the modulation index and in particular is the minimum when the modulation index is the maximum. Master Controller has to generate reference signal keeping the ripple low. To minimise the ripple amplitude of the output voltage of the dc 100 kV, 400Hz converter stages, the dc-link voltage is varied in order to maintain the duty-cycle of the inverters close to the maximum. This can be achieved in two ways: either 1) the reference of the dc-link voltage is generated in open loop OR 2) the reference of the dc-link voltage is generated as a function of the measured inverter duty-cycles, in order to maximize the duty-cycle of each stage without saturating the various modulation indexes.
- m) The reference voltage signal for each inverter unit shall be generated by the UHVPS-MC based on the signal set at MCP locally.
- n) In the event UHVPS-MC receives an external trip signal; a signal generated by the master controller shall turn off all the inverters switches for a prefixed time (10 ms) and during this time all the reference set values to be set to zero. After the prefixed time enable inverter switches to follow the output voltage reference provided by the master controller/PC. In the same time the dc-link voltage shall be maintained at the reference value.
- o) The HMI shall be equipped with:
- an operator panel equipped with LCD display for individual alarm, status, parameters indication, equipped with keyboard for parameter entry and system configuration;
 - a local/remote changeover facility;
 - an emergency button;
 - LED indicators for immediate display of the power supply status/alarms;



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

-
- control pushbuttons;
 - Conventional meters for analogue signals, if applicable.
- p) From the HMI, it shall be possible:
- To start a pulse for a variable pre-set time of reasonable limit;
 - To stop a pulse in progress;
 - To reset alarms;
 - To issue a variable pre-determined reasonable number of simulated load interruption and re-applications;
 - To display the output current and voltage and all relevant quantities for the operation of the UHVPS;
 - To set the output voltage and the variable duration of the rise in voltage;
 - To display the status of all interlocks, alarm and status signals;
 - To perform a test of all lamps and indicators;
 - To set the phase displacement among the 5 Inverters.
- q) The UHVPS-MC shall receive a number of measurements from the transducers installed inside the power equipment. Some measurements shall be used only for internal UHVPS operation and protection (e.g. dc-link voltage, dc-link current, output voltage/current etc...).
- r) The UHVPS-MC shall perform various protective actions. Depending on the type and severity of the fault it shall trip the AC mains 11 kV circuit breaker for overall system safety.
- s) The UHVPS-MC shall accept external request for protection action for which a well-defined protection sequence shall correspond. In general, all protection actions will be discussed, defined, and agreed during the detailed design/engineering stage of the contract.
- t) All the control signals to master controller will be through fibre optics. Even shielding of cable/ground should not come to the master controller.

6. ACCEPTANCE TESTS

6.1 Factory Acceptance Tests (FAT)

6.1.1 FAT for Inverter Module:

Each inverter module shall be tested in the Factory to the relevant IEC standard for dc/ac converters (IEC 60146-1, or equivalent). The following are some major tests that are to be performed by the supplier to demonstrate compliance of the inverter module as per the technical specifications prior to the shipment. All the related test equipment, fixtures, measuring instruments, test-setup, test load etc., shall be arranged by the supplier. Supplier shall submit a FAT template to IPR for review and approval. The details of the test template and testing procedure shall be done on mutual agreement after the award of contract. IPR representative shall witness the FAT at manufacturer's works.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

- a) Visual Inspection for Dimension, finish, and verification of BOM as per approved drawings.
- b) Heat run test for 8 hours of continuous operation and its stability measurements at rated power. (In case the full power test load or source is not available; then the test shall be conducted at mutually agreed reduced power level). During this test, temperature raise of crucial power components shall be monitored / recorded.
- c) Tests for compliance of major technical parameters viz. output voltage, power, frequency, THD and efficiency at maximum load feasible.
- d) Protection and Interlock test to check the inhibition of the output in less than 100 μ sec.
- e) Functional tests for effective operation and protection of inverter module. Different faults like over voltage, over current, over temperature and regulation errors shall be checked.
- f) Operational check of the feedback control loop with proper tuning of controller.
- g) Operational check of the disabling of driving pulses of the semiconductor devices through injection of all the tripping commands as specified in this tender document.
- h) Burn-in test on control circuit.
- i) Test for checking fibre optic communication for remote control operation.
- j) Test for checking fibre optic signal resolution, accuracy and proper operation etc.

6.1.2 FAT for Master Control Panel:

Master Controller shall be tested separately at the Factory. All the related test equipment, fixtures, measuring instruments, field simulators, test-setup, development of test jigs etc., shall be arranged by the supplier. Supplier shall submit a FAT template to IPR for review and approval. The details of the test template and testing procedure shall be done on approved plan after the award of contract. IPR representative shall witness the FAT at manufacturer's works.

- a. Checking of all monitoring and controlling parameters as listed in this tender document from MCP.
 - b. Field simulator Test for the Master Controller. Field signal condition to be implemented on simulator for testing.
 - c. Dynamic and Versatile testing of the controller.
 - d. Controller response time.
 - e. Test for checking Ethernet / RS232/485 interface communication between MCP and ROC/PC.
- The detailed test report including the test results shall be prepared by the supplier and submitted to purchaser for approval/ acceptance for dispatch clearance.

6.2 Site Acceptance Tests (SAT):

After the installation of Inverter Modules and MCP at IPR site; the SAT shall be performed in-line with FAT by the supplier. IPR at its discretion may prescribe all or a reduced subset of FAT tests to be performed at the IPR site. The tests shall include but not limited to following tests –



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

- a. Visual Inspection for Dimension, finish, Components and Hardware.
- b. Heat run test shall be carried out within rated parameters for 8 hours of continuous operation. During this test crucial performance parameters mentioned in the specification like voltage regulation, overall efficiency etc., shall be checked.
- c. Operational check of the feedback control loop with proper tuning of controller.
- d. Operational check of the disabling of driving pulses of the semiconductor devices through injection of all the tripping commands as specified in this tender document.
- e. Checking of all monitoring and controlling parameters as listed in this tender document from MCP.
- f. Integrated functional test and tuning of master controller with different local controllers as listed in tender document.

After the completion of SAT, the detailed test report including the test results shall be prepared by the supplier. The representative IPR and Supplier shall jointly sign the SAT test reports.

7. CONTRACT MANAGEMENT

7.1 Contract Execution Schedule:

The required delivery schedule for project execution which includes; Design, Procurements, Manufacturing, FAT, Delivery, Installation and SAT etc. is on or before 8 months from the date of approval of design and drawings submitted by the bidder after the award of contract. A preliminary project execution schedule which meets the overall delivery duration with major activities and milestones shall be submitted along with the bid. However, the bidder should submit a detailed project execution schedule which meets the targeted delivery time after award of contract.

7.2 Quality Assurance Plan (QAP):

The Inverter units and MCP shall be manufactured in conformance with the international and/or national standards/codes to assure the quality and reliability of the inverter system. Bidder should specify all the applicable standards followed. Bidder shall prepare a QAP or a manufacturing inspection plan which ensures the operational quality of the deliverables items under this contract. The same shall be submitted to IPR for its review and approval. QAP shall provide details of inspections/tests that will be carried out at various stages of the contract like design, engineering, procurements, manufacturing, assembly and testing.

7.3 Design and Drawing submission:

After the award of purchase order / contract, within 30 days the supplier must submit an Engineering Design and Drawings for the inverter unit and master control panel based on the



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

technical proposal submitted during the bid for IPR approval. This report shall include following minimum submission documents -

- a) Design calculations (electrical, thermal, mechanical etc.) and simulation reports including selection, and sizing of components shall be submitted
- b) Engineering design and drawings including GA drawings and electrical schematic drawings.
- c) Control block and schematic diagrams indicating Local / Remote controller interface etc.
- d) Cabling diagram and cable schedule with proper terminal block numbering.
- e) List of all accessories, and bill of materials (BOM).
- f) Data sheets/Catalogue of all the selected / bought-out major components viz. semiconductor devices; heat sinks, passive components like capacitors, resistors, inductors; current/voltage measuring sensors, protective elements, etc. used for making of inverter units and MCP shall be provided.
- g) Acceptance test procedures/criteria for FAT & SAT.
- h) Quality assurance plan.
- i) Schedule of execution.

7.4 Factory Acceptance Tests (FAT):

FAT shall be performed by the supplier to demonstrate compliance of the inverter unit and master control panel as per contract specifications before effecting the shipment, as per Section-6.1.

7.5 Operating and Instruction Manual:

The supplier shall submit 3 sets of document / technical literature in English language with complete layout, GA Drawings, detailed block diagrams and circuit diagrams of its assembly with test voltages at different test points of the unit. All aspects of installation, operation, maintenance and troubleshooting instructions as specified below shall be covered in this manual.

- a) Safety measures to be observed in handling of the equipment.
- b) Illustration of internal and external mechanical parts.
- c) Precautions at the time of installation, operation and maintenance.
- d) Procedures for trouble shooting, replacement and routine/preventive maintenance.
- e) Steps of remedial measures for troubleshooting the faults.
- f) Required Test Jigs and fixtures.
- g) Test instruments, test fixtures, accessories and tools required for maintenance and repair.
- h) List of replaceable parts used with the sources of procurement.
- i) A table giving details of sizes and dimensions of cable used
- j) Remedial steps for typical faults.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

7.6 Material Dispatch/Packing and Delivery:

After the review and approval of FAT report, a Dispatch Clearance Note shall be issued to supplier by IPR. All the deliverables (hardware and documents) shall be dispatched only after receiving a dispatch clearance note from IPR. However, a mere clearance issued by IPR will not relieve the supplier from the liability of proper functioning of inverter units at IPR Laboratory.

Appropriate safe packing, transportation (including Insurance) to IPR site are under the scope of the supplier, which shall include (but not limited to) a necessary list of documentation and appropriate packing, markings, labelling for the deliverables items. It must be noted that IPR shall not be liable for any of the damages cause during transit of the deliverables. The detailed packaging and transportation scheme shall be submitted to IPR well in advance.

7.7 Site Description:

The laboratory/delivery site is located in the **Institute for Plasma Research Campus, Near Indira Bridge, Bhat, Gandhinagar – 382 428, Gujarat, India**. The laboratory, where the inverter units to be installed is situated at ground floor level in IPR New Auxiliary Building.

7.8 Unloading and Storage:

Bidder is responsible for unloading of the inverter units, master control panel and accessories at proper locations at the site and verification of unit for damages and short supplies, making good all such damages and short supplies. The inverter units, master control panel and accessories shall be stored at Bidder's responsibility until final acceptance and taking over by IPR.

7.9 Installation:

The scope of work includes the installation of the following items-

- i. Inverter units.
- ii. Busbar/Cable connection between DC-Link terminals of Rectifier and individual Inverter unites.
- iii. Local Control Panel (if any)
- iv. Master Control Panel (MCP)
- v. Laying and termination of all type of interface cables viz. PVC insulated control cables, fibre optic cable, communication cables etc. between the Inverter units and Master Control Panel.
- vi. Laying and termination of all fibre optic cable between the Controlled Rectifier and HV Rectifier Local control Panel and Master Control Panel.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

Any material or accessory which may not have been specifically mentioned but which is necessary shall be supplied at no extra cost to IPR. *The installation must complete within 15 days after the material is delivered at site.*

7.10 Site Acceptance Tests (SAT):

SAT shall be performed by the supplier to demonstrate compliance of the inverter units and MCP as per contract specifications after effecting the installation, as per Section-6.2. *The SAT must complete within 15 days after the material is installed at site.*

7.11 Final Acceptance:

A final acceptance note shall be issued by IPR to the supplier after successful completion of SAT (and after resolving issues completely, if any) at site and submission of “As-built” marked-up drawings incorporating all modifications/changes made during manufacturing, testing and installation of the inverter units and master control panel. The date of issuance of final acceptance note shall be considered as the date of final acceptance.

7.12 Training:

The supplier has to arrange technical training of IPR representatives at IPR premises to familiarize about various sub-systems, operation and maintenance of this power supply.

7.13 Warranty:

Supplier should provide a minimum of one year standard warranty for all the deliverables (Inverter unit and all its accessories) thereof from the date of final acceptance issued by IPR.

Additionally, an optional one year extended warranty from the date of expiry of above specified minimum warranty is to be quoted separately.




Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

ANNEXURE – I



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

APPLICATION, FUNCTIONAL AND LAYOUT BLOCK DIAGRAM 500 kV UHVPS SYSTEM



Remarks : All optical fiber link between local control panel to mater control panel including transmitter and receiver unit will be in the scope of Master Controller

Figure-2: Block Diagram of 500kV DC Ultra High Voltage Power Supply (UHVPS)



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**




Figure-3: Block diagram of Control architecture of the 500kV UHVPS for reference only



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**




Figure 4: Programmed function of Master Controller (for reference only)



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**




Figure-5: Signal Interface Diagram of Master Control Panel (MCP)



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**




Figure-6: Tentative site lay out plan



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

Table-3: Tentative Listing of Interfacing Signals with Master Control Panel (MCP)

Sr. No.	Signal	Physical Type	Signal Type	From	To
1.	From Regulated AC/DC Converter (Rectifier) Local Control Panel (Rectifier-LCP)				
a.	Input Voltage	OFC	0-10V/4-20mA	Rectifier-LCP	MCP
b.	Input Current	OFC	0-10V/4-20mA	Rectifier-LCP	MCP
c.	ON/OFF/Trip status	OFC	PFC	Rectifier-LCP	MCP
d.	Trip/OFF	OFC	PFC	MCP	Rectifier-LCP
e.	Output Voltage reference setting	OFC	0-10V/4-20mA Reconfigurable	MCP	Rectifier-LCP
f.	Protection Setting: Over Voltage and Current threshold	OFC	0-10V/4-20mA Reconfigurable	MCP	Rectifier-LCP
g.	Local /Remote	OFC	PFC	MCP	Rectifier-LCP
h.	AC /DC Converter Enable/Disable	OFC	PFC	MCP	Rectifier-LCP
i.	Emergency OFF	OFC	PFC	MCP	Rectifier-LCP
j.	DCPS Reset	OFC	PFC	MCP	Rectifier-LCP
k.	Interlock & Safety	OFC	PFC	Rectifier-LCP	MCP
l.	Protection Trip Status	OFC	PFC	Rectifier-LCP	MCP
m.	Local /Remote Switch Status	OFC	PFC	Rectifier-LCP	MCP
n.	DCPS Power Panel Temperature	OFC	PFC	Rectifier-LCP	MCP
o.	DCPS Control Panel Temperature	OFC	PFC	Rectifier-LCP	MCP
2.	DC/AC Converter (Inverter) Local Control Panel (5 units) (Inverter-LCP)				
a.	AC Output Voltage	OFC	0-10V/4-20mA	Inverter-LCP	MCP
b.	AC output Current	OFC	0-10V/4-20mA	Inverter-LCP	MCP
c.	Output Voltage reference setting	OFC	0-10V/4-20mA Reconfigurable	MCP	Inverter-LCP
d.	Protection Setting: Over Voltage and Current threshold	OFC	0-10V/4-20mA Reconfigurable	MCP	Inverter-LCP
e.	DC link Voltage	OFC	0-10V/4-20mA	Inverter-LCP	MCP
f.	Input Switch on/OFF	OFC	PFC	MCP	Inverter-LCP
g.	DC Link Capacitor Discharge Switch ON/OFF	OFC	PFC	MCP	Inverter-LCP
h.	Pulse Enable /Disable	OFC	PFC	MCP	Inverter-LCP



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

i.	Inverter ON/OFF	OFC	PFC	MCP	Inverter-LCP
j.	Local /Remote	OFC	PFC	MCP	Inverter-LCP
k.	Interlock & Safety	OFC	PFC		MCP
l.	Emergency OFF	OFC	PFC	MCP	Inverter-LCP
m.	Protection Trip Status	OFC	PFC	Inverter-LCP	MCP
n.	Inverter Power Panel Temperature	OFC	PFC	Inverter-LCP	MCP
o.	Inverter Control Panel Temperature	OFC	PFC	Inverter-LCP	MCP
p.	Inverter Reset	OFC	PFC	MCP	Inverter-LCP
q.	Local /Remote Switch Status	OFC	PFC	Inverter-LCP	MCP
3.	From High Voltage Transformer Rectifier LCP (5 units) (HV Rectifier-LCP)				
a.	Stage wise DC output Voltage	OFC	0-10V/4-20mA	HV Rectifier-LCP	MCP
b.	Stage wise DC output Current	OFC	0-10V/4-20mA	HV Rectifier-LCP	MCP
c.	Tank Temperature	OFC	PFC	HV Rectifier-LCP	MCP
d.	Trip Signal	OFC	PFC	HV Rectifier-LCP	MCP
e.	Interlock & Safety	OFC	PFC	HV Rectifier-LCP	MCP
f.	Trip Status	OFC	PFC	HV Rectifier-LCP	MCP
g.	Transformer Oil/Winding Temperature	OFC	PFC	HV Rectifier-LCP	MCP
h.	Pressure Release Valve Status	OFC	PFC	HV Rectifier-LCP	MCP
i.	Control Panel Temperature	OFC	PFC	HV Rectifier-LCP	MCP
4.	Load				
a.	Trip Signal	OFC	PFC	Load	MCP
b.	Earth Switch Status	OFC	PFC	Load	MCP
5.	Remote Operation Console/PC (ROC)				
a.	Configurable Inputs	Wired	PFC	Remote Console	MCP
b.	Interlock & Safety Status	Wired	PFC	MCP	Remote Console



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

c.	Trip Status	Wired	PFC	MCP	Remote Console
d.	Emergency off	Wired	PFC	MCP	MCP
e.	Remote/Local Selection	Wired	PFC	Remote Console	MCP
f.	Output Display	Wired	PFC	MCP	Remote Console
g.	Reset	Wired	PFC	Remote Console	MCP
h.	Communication protocol	Ethernet/RS484			

Note: The above listing of interface signals for master control panel is only indicative and tentative for reference/estimation only the detailed listing of signals shall be mutually worked out between purchaser and supplier during detailed design phase.

- ❖ All the control signal to master controller will be through fibre optics cable even shielding of cable/ground should not come to the master controller.
- ❖ The scope of supply includes supply of all types of cable viz. PVC, fibre optic as may be required for total integration of 500 kV UHVPS.



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

ANNEXURE – II

TECHNICAL BID COMPLIANCE

Bidder must submit along with the bid the following documents –

- a) Conceptual technical proposal including GA drawings, Block Diagrams etc.
- b) Thermal analysis and basis of components selection
- c) Tentative Bill of material (BOM)
- d) Proof of concept/topology together with simulation report/results
- e) Justification of Topology for critical Technical Parameters.
- f) Suggested spares.
- g) Data sheet duly filled in data against each parameter. Just filling “complied” shall not be accepted, the actual offered value must be indicated.
- h) Tentative contract execution schedule defining major activities / milestones

During the evaluation of technical bids, IPR shall review the submitted technical proposal and may seek further clarifications/discussions with the bidder to ascertain feasibility or viability of the same. If the proposal is found to be incapable of meeting the technical specifications, the bid shall be technically disqualified.

Table-4: Inverter Unit Data Sheet

Sr. No.	Parameters	Bidder's Data
1.	Site Condition	
a.	Ambient Temperature (maximum/minimum/average (annual))	
b.	Relative Humidity (maximum / minimum)	
c.	Altitude	
d.	Installation	Indoor / Outdoor
2.	Input Supply	
a.	Input Voltage	
b.	Input voltage variation under steady state condition	
c.	Input voltage variation under transient state condition	
3.	Performance Requirement	
a.	Inverter topology	Provide tentative schematic design drawing and simulation results



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

b.	AC output power	
c.	AC output voltage	
d.	AC output frequency	
e.	Output voltage wave form	
f.	Output Power factor	
g.	Number of Phases	
h.	Efficiency	
i.	Total Harmonic Distortion (THD) %	
j.	Output overloading	
k.	Output Voltage Control/Regulation range	
l.	Control precision	
m.	Regulation	
n.	Response time	
o.	Type of Cooling	
p.	Protection class	
q.	Protection	Provide the list of protections considered in design of Inverter units
r.	Inverter unit Power panel design, degree of protection	
s.	Inverter unit power panel shipment dimensions and weight	
4.	Inverter unit Local Control Panel	
a.	Make and Type	
b.	Mode of Operation	Local/Remote
c.	Measurements and Display	List all Measurement and Display provided
d.	Control Parameters	List all control parameters and mechanism
e.	Controller Type, Manufacture	
f.	Interface hardwired signals for remote controller	List all monitoring and control interface signals to be provided
g.	Industrial Touch Panel Display (HMI) provided: if yes Type, model no. , make, processor, memory, screen display size. etc...	
h.	Degree of Protection	
i.	Cooling	Forced/Natural Air
j.	Shipping Dimension & Weight	Meter / kg
k.	Applicable Standard	
5.	DC/AC Converter (Inverter) terminations:	



Technical Specification for Design, Engineering, Manufacturing, Inspection, Factory Acceptance Testing, Supply, Installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400 V, 400 Hz Three Phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel. **(SECTION-C)**

a.	Input	Define type and size of power connection
b.	Output	Define type and size of power connection
6.	Applicable Standards	List all applicable IS/IEC standards

Table-5: Master Control Panel Data Sheet

Sr. No.	Parameters	Bidder's Data
a.	Make and Type	
b.	Controller Type, Manufacture	
c.	Interface hardwired signals and type	List all monitoring and control interface signals to be provided
d.	Industrial Touch Panel Display (HMI) provided: if yes Type, model no. , make, processor, memory, screen display size. etc...	
e.	Degree of Protection	
f.	Cooling	Forced/Natural Air
g.	Shipping Dimension & Weight	Meter / kg
h.	Applicable Standard	List all applicable IS/IEC standards

Institute for Plasma Research
(An Autonomous Institute of Dept. of Atomic Energy)
Bhat, Gandhinagar

TERMS & CONDITIONS

ITEM DESCRIPTION	Design, Engineering, Manufacturing, inspection, factory acceptance testing, supply, installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400V, 400 Hz, Three phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel as per the specifications given in the tender documents.	
Sl. No.	PARTICULARS	REMARKS
I	Name of the Supplier	
II	IPR Enquity NO & Date	IPR/TN/PUR/TPT/ET/18-19/46 DATED 9-1-2019
III	Vendor Offer No & Date	
IV	Postal address	
V	Contact with STD code	
VI	Fax with STD code	
VII	Name of Contact person	
VIII	Mobile No.	
IX	e-mail ID	
X	Currency of offer/quotation	
	SCANNED COPY OF THE BELOW MENTIONED DOCUMENTS NEED TO UPLOAD AT www.tenderwizard.com/DAE AT THE TIME OF PARTICIPATION OF TENDER WITHIN THE PERIOD OF SUBMISSION.	"YES" OR "NO"
1	Certificates:	
	i) Registration Certificate if Any, with DGS&D/NSIC/MSME	
	ii) PAN (Permanent Account Number) Registration	
	iii) Certificates of Registration for Sales Tax/ VAT/ WCT or Service Tax	
	iv) Authorization certificate/ Agency Agreement from Manufacturer (if not manufacturer)	
	Commercial Terms for Quoted items (Please Provide Commercial terms and conditions in the below form)	
2	Price Shall be firm and fixed through out the currency of contract, in the event of placement of purchase order.	
3	Please select the CURRENCY OF OFFER / QUOTATION first	
4	Have you offered Packing and forwarding charges in the price bid (if applicable)?	
5	Goods and Services Tax: Have you specified HSN / SAC Code for Goods and Services Tax in Price Bid?	
6	Have you offered Freight charges in the price bid?	
7	Have you offered Insurance charges in the price bid?	
8	Delivery period (as per Sr. No.31 of Section-A of Form No. IPR_LP_ET_02.V5 (Terms and Conditions) attached with the tender/enquiry). (Also refer document named "Deferred_terms_IPR_LP_ET_02.V5" for amended delivery terms)	
9	Have you offered Installation and commissioning charges?	
10	Liquidated Damages:- as per Sr. No. 22 of Section B of Form No IPR-LP-ET-02.V5 (Terms and Conditions) attached with the tender/enquiry	
11	Terms of Payment:- as per Sr. No.35 of Form No. IPR_LP_ET_02.V5 (Terms and Conditions) attached with the tender/enquiry. (Also refer document named "Deferred_terms_IPR_LP_ET_02.V5" for amended payment terms)	
12	Guaranty / Warranty:-as per Sr. No. 34 of f Form No. IPR_LP_ET_02.V5 (Terms and Conditions) attached with the tender/enquiry	
13	Validity of offer/quotation:- 120 days from the date of opening of tender	
	QUESTIONNAIRE TO BE FILLED BY BIDDER IN AND SENT ALONG WITH OFFER DULY SIGNED	
14	In the event of a purchase order/contract vendor has to provide Security Deposit in the form of Bank Guarantee for 10% of contract/ order value from SBI/nationalized banks or any one of the scheduled banks mentioned in the bracket (Axis Bank, HDFC Bank, ICICI Bank and IDBI Bank) valid till final acceptance of the supplied goods at IPR, wherever applicable shall be submitted .	
15	In the event of a purchase order/contract Performance Bank Gurantee for 10% of the contract/order value from SBI/nationalized banks or any one of the scheduled banks mentioned in the bracket (Axis Bank, HDFC Bank, ICICI Bank and IDBI Bank) valid throughout the guarantee period, wherever applicable shall be submitted.	

16	I/We hereby offer to supply the stores detailed in the schedule hereto at the price given in the said schedule and agree to hold this offer open till expiry of quotation. I/We shall be bound to supply the stores hereby offered upon issue of purchase order communicating the acceptance thereof on or before the expiry of the last mentioned date. You will be at liberty to accept any one or more of the items of stores tendered for or portion of any or more of the items of such stores and I/We notwithstanding that the offer in the tender has not been accepted in whole shall be bound to supply to you- such item or items and such portion or portions of one or more of the items as may be specified in the said Purchase Order communicating the acceptance.	
17	I/we have understood the General Conditions of all Contracts and special conditions of contract governing supplies of plant and machinery in the Form No.IPR_LP_ET_02.V5, included in the General Conditions of all Contracts and special conditions of contract governing of plant and machinery applicable to contracts placed by the Institute for Plasma Research and the instructions to Tenderer annexed to the invitation to tender Form and have thoroughly examined the specification / drawing and / or pattern quoted or referred to in the Schedule hereto and am/are fully aware of the nature of the stores required any my/our offer is to supply stores strictly in accordance with subject tender to the terms and conditions stipulated in your above Form No. IPR_LP_ET_02.V5 and also contained in the Purchase Order Communicating acceptance of this Tender.	
18	Whether All Documents Related to tender Viewed?	
19	Vendor should upload the complete technical details (Tehnical specifications with product data sheet	
20	In case of two part tender whether unpriced quotation has been uploaded (Failing which offer will not be considered for technical evaluation)	
21	Free Issue Material: Successful tenderer will have to arrange insurance showing beneficiary as "Institute for Plasma Research" at their risk and cost towards adequate security for the materials/property provided/issued by the Purchaser as Free Issue Material for the due execution of the contract, wherever applicable.	

Institute for Plasma Research
(An Autonomous Institute of Dept. of Atomic Energy)
Bhat, Gandhinagar

Eligibility Criteria (Annexure-A)

ITEM DESCRIPTION	Design, Engineering, Manufacturing, inspection, factory acceptance testing, supply, installation and Site Acceptance Testing of 3 (three) units of 300 kVA, 400V, 400 Hz, Three phase Sine Wave Solid State Regulated DC to AC Converter (Inverter) System and 1 (one) unit of Master Control Panel as per the specifications given in the tender documents.		
Sl. No.	PARTICULARS	REMARKS	
I	Name of the Vendor		
II	IPR Enquiry NO & Date	IPR/TN/PUR/TPT/ET/18-19/46 DATED 9-1-2019	
III	Vendor Offer No & Date		
Sr. No.	Criteria	Documents required to upload	Status of Documents (Uploaded/ Not-Uploaded in e-Tender Portal)
1	The Bidder must be an Original Equipment Manufacturer (OEM) of Power Electronic Equipments	Bidder should submit company profile and documents supporting to the same	
2	The Bidder must have manufactured and supplied at least one (01) DC to AC Converters (Inverter) of rating greater than or equal to 100 kVA	Bidder should submit the copies of purchase orders with technical details along with completion/installation certificate.	

Note:

The response to tender without submission of proof of above points will summarily be rejected without further communication
The bidder shall not be under a declaration of ineligibility for corrupt or fraudulent practices or blacklisted with any of the Government agencies
Original documents shall be produced for verifications, if required.

PRICE SCHEDULE (SECTION-D)

IPR Enquiry NO & Date : **IPR/TN/PUR/TPT/ET/18-19/46 DATED 9-1-2019**

From

NAME OF THE CONTRACTOR :

Offer no & date:

Sl.No	Item Description	Tendered Quantity	Unit of Measurement	Rate in INR			Packing and Forwarding		Freight Charges Per Unit		Insurance per unit		Remarks
				HSN Code (*1)	Basic Unit Rate	Discount (in amount)	Basic Unit rate after discount	(in %) Only	Amount	(in %) Only	Amount	(in %) Only	
1	Design, Engineering, Manufacturing, Supply, 300 kVA, 400 V, 400 Hz. Three Phase Sine Wave Solid State Regulated DC /AC Converter (Inverter) system	3	Nos				0.00		0.00		0.00		
2	Installation, Testing, and Commissioning of 300 kVA, 400 V, 400 Hz. Three Phase Sine Wave Solid State Regulated DC /AC Converter (Inverter) system (including unloading, shifting, handling with accessories)	3	Nos				0.00		0.00		0.00		
3	Design, Engineering, Manufacturing, testing and Supply of Master Control Panel	1	Nos				0.00		0.00		0.00		
4	Installation and Site Acceptance Testing of Master Control Panel (including unloading, shifting, handling with accessories)	1	Nos				0.00		0.00		0.00		
5	Recommended Spares (provide the list of spare with quantity provided)	1	Set				0.00		0.00		0.00		
6	Test jig for analog and digital, input output signal simulations	1	Set				0.00		0.00		0.00		
7	Additional one year warranty charges in addition to the minium warranty quoted by bidder (Optional)	1	lumpsum				0.00		0.00		0.00		
8	Other items (if any)												
a	Optional Item/ Accessories						0.00		0.00		0.00		
b	Optional Item/ Accessories						0.00		0.00		0.00		
c	Optional Item/ Accessories						0.00		0.00		0.00		
d	Optional Item/ Accessories						0.00		0.00		0.00		
e	Optional Item/ Accessories						0.00		0.00		0.00		

Place of delivery **IPR Gandhinagar**

NOTES:

- (a) If freight is not shown seperately it will be treated as "FREE DELIVERY" (applicable for INR Quote)
- (b) Detailed specifications and scope of work are as per Attached Annexure
- (c) If the rate cells are left blank, it will be treates as "0" (ZERO)
- (e) Kindly enable the Macros if you receive the "Security Warning" message. (Click on options in "Security Warning" and select "Enable this content")

- IMPORTANT NOTES:**
- 1) Custom Duty Exemption certificate will not be issued to any bidder under any circumstances.
 - 2) Prices in this bid format alone are acceptable
 - 3) GST (IGST, CGST, SGST or any form) should not be included in the basic cost (Unit Rate Column) for either goods or services
 - 4) Evaluated total cost on the basis of bid prices will be calculated by Purchaser after bid opening.

(*1) HSN/SAC Code: For indigenous goods/services, to be filled by the bidder

1) QUOTATIONS ARE INVITED IN INDIAN CURRENCY ONLY.

2) QUOTATIONS RECEIVED OTHER THAN “INR” QUOTE SHALL SUMMARILY BE REJECTED.

(This need to be printed in Tenderer's letter head)

To
The Purchase Officer
Institute for Plasma Research
Near Indira Bridge
Bhat
Gandhinagar-382428 (INDIA)

**Ref: Tender Notice No.IPR/TN/PUR/TPT/ET/18-19/46 dated
9/1/2019**

Dear Sir,

I/We have gone through the tendering conditions pertaining to the Two Part Tender and General Conditions of Contracts and Special Conditions of Contracts contained in Section "B" of Form No: IPR-LP-ET-02.V5. I/We hereby agree to supply the stores conforming to the tender specifications and also agree to abide by your General Conditions of all Contracts and Special Conditions of Contract contained in Section "B" of the Tender document.

- You will be at liberty to accept any one or more of the items of stores offered by us and I/We shall be bound to supply you the stores as may be specified in the Purchase Order/Contract.
- I/We hereby agree to keep the price valid for your acceptance for a period of 120 days from the date of opening of Part-II (Price) of the tender.
- Deviations to technical specifications of the tender documents are detailed in Annexure-A of the tender form while deviations proposed to the General/Special Conditions of Contract are detailed in Annexure "B" to this tender.
- I/We are also uploaded all the leaflets/catalogue, etc. pertaining to the stores offered.

Yours faithfully
Stamp and Signature of the Tenderer